

	Punct de recoltare	Parametrii analizati															
		Clor rezidual liber [mg/l]	Turbiditate [NTU]	Culoare	Gust	pH [unitati pH]	Conductivitate [μ S/cm]	Duritate [$^{\circ}$ G]	Subst. organice [mg O ₂ /l]	Nitriti [mg/l]	Amoniu [mg/l]	Azoati [mg/l]	*Bacterii coliforme [nr/100 ml]	*E. coli [nr/100 ml]	*Enterococi intestinali [nr/100 ml]	*UFC 37 $^{\circ}$ C/ml	*UFC 22 $^{\circ}$ C/ml
CMA		$\geq 0.1 - \leq 0.5$	max5	incolor	Acc cons	5.6-9.5	Max 2500	min5	max5	≥ 0.5	≥ 0.5	≥ 50	0	0	0	nicio modificare anormala	nicio modificare anormala
	Pizzeria Play, Str Eminescu, nr 124	0.51	1.11	inc	Acc cons	6.88 / 19.6 $^{\circ}$ C	79.3	1.96	0.64	<0.0208	<0.0141	1.06	0	0	0	0	0
	Rest. Davos, Str Cernei nr. 10	0.52	1.36	inc	Acc cons	6.80 / 19.0 $^{\circ}$ C	79.8	1.96	0.90	<0.0208	<0.0141	0.62	0	0	0	0	0
	Liceul de arte S. Toduta, Str Liliacului	0.50	0.50	inc	Acc cons	6.72 / 19.4 $^{\circ}$ C	81.9	2.02	0.57	<0.0208	<0.0141	0.89	0	0	0	0	0
	Liceul Tehn Energ Hurmuzescu (Sc Gen nr 6), Str Bejan	0.53	1.20	inc	Acc cons	6.95 / 22.2 $^{\circ}$ C	80.6	2.02	1.07	<0.0208	<0.0141	1.02	0	0	0	0	0

Marcket Auchan	0.51	0.87	inc	Acc cons	6.72 / 19.5°C	84.1	2.19	0.64	<0.0208	<0.0141	1.73	0	0	0	0	0
Centrul de transfuzii	0.49	0.93	inc	Acc cons	6.69 / 19.4°C	85.7	2.31	0.64	<0.0208	<0.0141	1.31	0	0	0	0	0
Gradinita PP6, Str A Iancu	0.71	0.99	inc	Acc cons	6.51 / 20.3°C	85.2	2.19	0.96	<0.0208	<0.0141	1.35	0	0	0	0	0

Monitorizarea calitatii apei potabile luna ianuarie 2019

Sector DEVA

Monitorizarea calitatii apei potabile luna ianuarie 2019

Sector DEVA – Certej

	Punct de recoltare	Parametrii analizati															
		Clor rezidual liber [mg/l]	Turbiditate [NTU]	Culoare	Gust	pH [unitati pH]	Conductivitate [μS/cm]	Duritate [°G]	Subst. organice [mg O ₂ /l]	Nitriti [mg/l]	Amoনি [mg/l]	Azoți [mg/l]	*Bacterii coliforme [nr/100 ml]	*E. coli [nr/100 ml]	*Enterococi intestinali [nr/100 ml]	*UFC 37°C/ml	*UFC 22°C/ml
CMA		≥0.1-≤0.5	Max 5	incolor	Acc cons	5.6-9.5	Max 2500	min5	max5	≥0.5	≥0.5	≥50	0	0	0	nicio modificare anormala	nicio modificare anormala
	Primaria Certej	0.51	2.65	inc	Acc cons	7.20 / 19.6°C	390	8.65	0.70	<0.0208	<0.0141	-	0	0	0	0	0

Monitorizarea calitatii apei potabile luna ianuarie 2019

Sector DEVA – Dobra

	Punct de recoltare	Parametrii analizati															
		Clor rezidual liber [mg/l]	Turbiditate [NTU]	Culoare	Gust	pH [unitati pH]	Conductivitate [μ S/cm]	Duritate [$^{\circ}$ G]	Subst. organice [mg O ₂ /l]	Nitriti [mg/l]	Amoniu [mg/l]	Azoati [mg/l]	*Bacterii coliforme [nr/100 ml]	*E. coli [nr/100 ml]	*Enterococi intestinali [nr/100 ml]	*UFC 37 $^{\circ}$ C/ml	*UFC 22 $^{\circ}$ C/ml
CMA		$\geq 0.1 - \leq 0.5$	Max 5	incolor	Acc cons	5.6-9.5	Max 2500	min5	max5	≥ 0.5	≥ 0.5	≥ 50	0	0	0	nicio modificare anormala	nicio modificare anormala
	Gurasada consumator	0.44	1.17	inc	Acc cons	7.26 / 19.8 $^{\circ}$ C	230	7.27	0.70	<0.0208	<0.0141	2.96	0	0	0	0	0

Monitorizarea calitatii apei potabile luna ianuarie 2019

Sector DEVA – Mintia, Lesnic Vetel

	Punct de recoltare	Parametrii analizati															
		Clor rezidual liber [mg/l]	Turbiditate [NTU]	Culoare	Gust	pH [unitati pH]	Conductivitate [μ S/cm]	Duritate [$^{\circ}$ G]	Subst. organice [mg O ₂ /l]	Nitriti [mg/l]	Amoনিu [mg/l]	Azoți [mg/l]	*Bacterii coliforme [nr/100 ml]	*E. coli [nr/100 ml]	*Enterococi intestinali [nr/100 ml]	*UF C 37°C/ml	*UF C 22°C/ml
CMA		$\geq 0.1 - \leq 0.5$	Max 5	incolor	Acc cons	5.6-9.5	Max 2500	min5	max5	≥ 0.5	≥ 0.5	≥ 50	0	0	0	nicio modificare anormala	nicio modificare anormala
	Lesnic consumator	0.42	0.95	inc	Acc cons	6.86 / 20°C	82.3	2.08	0.76	<0.0208	<0.0141	1.56	0	0	0	0	0

Monitorizarea calitatii apei potabile luna ianuarie 2019

Sector CALAN

	Punct de recoltare	Parametrii analizati															
		Clor rezidual liber [mg/l]	Turbiditate [NTU]	Culoare	Gust	pH [unitati pH]	Conductivitate [μ S/cm]	Duritate [$^{\circ}$ G]	Subst. organice [mg O ₂ /l]	Nitriti [mg/l]	Amoনিu [mg/l]	Azoati [mg/l]	*Bacterii coliforme [nr/100 ml]	*E. coli [nr/100 ml]	*Enterococi intestinali [nr/100 ml]	*UFC 37 $^{\circ}$ C/ml	*UFC 22 $^{\circ}$ C/ml
CMA		$\geq 0.1 - \leq 0.5$	Max 5	incolor	Acc cons	5.6-9.5	Max 2500	min5	max5	≥ 0.5	≥ 0.5	≥ 50	0	0	0	nicio modificare anormala	nicio modificare anormala
	Scoala Veche, Calan ON	0.39	1.08	inc	Acc cons	6.88 / 19.1 $^{\circ}$ C	79.3	1.91	0.70	<0.0208	<0.0141	1.20	0	0	0	0	0
	Breteia Romana Primarie	0.76	0.76	inc	Acc cons	6.66 / 19.1 $^{\circ}$ C	80.5	2.02	0.80	<0.0208	<0.0141	1.02	0	0	0	0	0
	Maceu Magazin15	0.30	1.13	inc	Acc cons	6.86 / 19.5 $^{\circ}$ C	83.5	2.02	1.15	<0.0208	<0.0141	1.62	0	0	0	0	0

Monitorizarea calitatii apei potabile luna ianuarie 2019

Sector SIMERIA

	Punct de recoltare	Parametrii analizati															
		Clor rezidual liber [mg/l]	Turbiditate [NTU]	Culoare	Gust	pH [unitati pH]	Conductivitate [μ S/cm]	Duritate [$^{\circ}$ G]	Subst. organice [mg O ₂ /l]	Nitriti [mg/l]	Amoniu [mg/l]	Azoati [mg/l]	*Bacterii coliforme [nr/100 ml]	*E. coli [nr/100 ml]	*Enterococi intestinali [nr/100 ml]	*UFC 37 $^{\circ}$ C/ml	*UFC 22 $^{\circ}$ C/ml
CMA		$\geq 0.1 - \leq 0.5$	Max 5	incolor	Acc cons	5.6-9.5	Max 2500	min5	max5	≥ 0.5	≥ 0.5	≥ 50	0	0	0	nicio modificare anormala	nicio modificare anormala
	Restaurant Bacia	0.82	0.62	inc	Acc cons	6.61 / 21.5 $^{\circ}$ C	82.2	2.83	0.89	<0.0208	<0.0141	1.16	0	0	0	0	0
	Liceul A Saligni, Zona II Simeria	0.20	1.20	inc	Acc cons	6.59 / 22.0 $^{\circ}$ C	82.7	2.08	1.15	<0.0208	<0.0141	1.06	0	0	0	0	0
	Camin Copii, Zona I Simeria	0.50	0.88	inc	Acc cons	6.82 / 20.0 $^{\circ}$ C	85.3	2.36	0.70	<0.0208	<0.0141	1.47	0	0	0	0	0