

Monitorizarea calitatii apei potabile luna februarie 2019

Sector DEVA

| | Punct de recoltare | Parametrii analizati | | | | | | | | | | | | | | | |
|-------------|-------------------------------------|-----------------------------|-------------------|---------|----------|--------------------------|------------------------------|--------------------------|--|----------------|---------------|---------------|---------------------------------|----------------------|-------------------------------------|----------------------------------|----------------------------------|
| | | Clor rezidual liber [mg/l] | Turbiditate [NTU] | Culoare | Gust | pH [unitati pH] | Conductivitate [μ S/cm] | Duritate [$^{\circ}$ G] | Subst. organice [mg O ₂ /l] | Nitriti [mg/l] | Amoniu [mg/l] | Azoati [mg/l] | *Bacterii coliforme [nr/100 ml] | *E. coli [nr/100 ml] | *Enterococi intestinali [nr/100 ml] | *UFC 37 $^{\circ}$ C/ml | *UFC 22 $^{\circ}$ C/ml |
| CM A | | $\geq 0.1 - \leq 0.5$ | max5 | incolor | Acc cons | 5.6-9.5 | Max 2500 | min5 | max5 | ≥ 0.5 | ≥ 0.5 | ≥ 50 | 0 | 0 | 0 | nicio modificare anormala | nicio modificare anormala |
| | Pizzeria Play, Str Eminescu, nr 124 | 0.66 | 1.32 | inc | Acc cons | 6.51 / 22.0 $^{\circ}$ C | 85.5 | 2.02 | 0.84 | <0.0208 | <0.0141 | 1.18 | 0 | 0 | 0 | 0 | 0 |
| | Spital Judetean | 0.33 | 0.77 | inc | Acc cons | 6.75 / 21.1 $^{\circ}$ C | 86.3 | 2.08 | 0.77 | <0.0208 | <0.0141 | 1.42 | 0 | 0 | 0 | 0 | 0 |
| | Piata Centrala | 0.10 | 1.66 | inc | Acc cons | 6.77 / 21.5 $^{\circ}$ C | 87.7 | 2.02 | 0.71 | <0.0208 | <0.0141 | 1.03 | 0 | 0 | 0 | 0 | 0 |
| | Brutaria Panaur, Str N. Balcescu | 0.34 | 1.06 | inc | Acc cons | 6.53/ 18.4 $^{\circ}$ C | 80.5 | 2.19 | 0.65 | <0.0208 | <0.0141 | 1.96 | 0 | 0 | 0 | 0 | 0 |
| | Cofetaria Eis, Str V. Babes | 0.51 | 3.07 | inc | Acc cons | 6.76/ 19.3 $^{\circ}$ C | 82.2 | 2.25 | 0.84 | <0.0208 | <0.0141 | 1.70 | 0 | 0 | 0 | 0 | 0 |

| | | | | | | | | | | | | | | | | |
|-----------------------------------|------|------|-----|----------|---------------|------|------|------|---------|---------|------|---|---|---|---|---|
| Pensiunea Diana, Calea Zarandului | 0.77 | 1.26 | inc | Acc cons | 6.61/20.1°C | 90.1 | 2.25 | 0.71 | <0.0208 | <0.0141 | 1.62 | 0 | 0 | 0 | 0 | 0 |
| Scoala Gen. Transilvania | 0.78 | 0.96 | inc | Acc cons | 6.58 / 20.1°C | 89.4 | 2.36 | 0.64 | <0.0208 | <0.0141 | 1.31 | 0 | 0 | 0 | 0 | 0 |
| S.C.Unicar m Str Bejan | 0.58 | 1.02 | inc | Acc cons | 6.96 / 20.0°C | 90.7 | 2.42 | 0.64 | <0.0208 | <0.0141 | 1.35 | 0 | 0 | 0 | 0 | 0 |
| Colegiul Tehnic Transilvania | 0.88 | 1.03 | inc | Acc cons | 6.59 / 20.7°C | 90.8 | 2.28 | 1.25 | <0.0208 | <0.0141 | 0.70 | 0 | 0 | 0 | 0 | 0 |
| Petrom Sântuhalm | 0.83 | 0.98 | inc | Acc cons | 6.51 / 20.3°C | 91.1 | 2.22 | 0.70 | <0.0208 | <0.0141 | 1.21 | 0 | 0 | 0 | 0 | 0 |

| Punct de recoltare | Parametrii analizati | | | | | | | | | | | | | | | |
|--------------------|----------------------------|-------------------|----------------|-----------------|-----------------|------------------------------|---------------|--|----------------|---------------|---------------|---------------------------------|----------------------|-------------------------------------|----------------------------------|----------------------------------|
| | Clor rezidual liber [mg/l] | Turbiditate [NTU] | Culoare | Gust | pH [unitati pH] | Conductivitate [μ S/cm] | Duritate [°G] | Subst. organice [mg O ₂ /l] | Nitriti [mg/l] | Amoniu [mg/l] | Azoati [mg/l] | *Bacterii coliforme [nr/100 ml] | *E. coli [nr/100 ml] | *Enterococi intestinali [nr/100 ml] | *UFC 37°C/ml | *UFC 22°C/ml |
| CMA | $\geq 0.1 - \leq 0.5$ | max5 | incolor | Acc cons | 5.6-9.5 | Max 2500 | min5 | max5 | ≥ 0.5 | ≥ 0.5 | ≥ 50 | 0 | 0 | 0 | nicio modificare anormala | nicio modificare anormala |
| ABC Balata | 0.10 | 1.12 | inc | Acc cons | 6.64 / 19.8°C | 89.4 | 2.30 | 0.79 | <0.0208 | <0.0141 | 1.43 | 0 | 0 | 0 | 0 | 0 |

| | | | | | | | | | | | | | | | | |
|------------------|------|------|-----|----------|-----------------|------|------|------|---------|---------|------|---|---|---|---|---|
| Chiscadaga nr 89 | 0.23 | 0.93 | inc | Acc cons | 6.77 19.8°C | 89.2 | 2.42 | 0.73 | <0.0208 | <0.0141 | 1.62 | 0 | 0 | 0 | 0 | 0 |
| Primaria Soimus | 0.18 | 1.05 | inc | Acc cons | 7.30/ 19.6°C | 92.6 | 2.28 | 0.57 | <0.0208 | <0.0141 | 1.99 | 0 | 0 | 0 | 0 | 0 |
| Cantina Soimus | 0.14 | 1.07 | inc | Acc cons | 7.13/ 19.6°C | 92.1 | 2.28 | 0.57 | <0.0208 | <0.0141 | - | 0 | 0 | 0 | 0 | 0 |
| Chiscadaga nr 89 | 0.10 | 3.45 | inc | Acc cons | 7.09/ 19.8°C | 92.2 | 2.34 | 0.64 | <0.0208 | <0.0141 | 2.12 | 0 | 0 | 0 | 0 | 0 |

Monitorizarea calitatii apei potabile luna februarie 2019

Sector DEVA – zona Șoimuș

Monitorizarea calitatii apei potabile luna februarie 2019

Sector CĂLAN

| | Punct de recoltare | Parametrii analizati | | | | | | | | | | | | | | | |
|------------|--------------------|----------------------------|-------------------|----------------|-----------------|-----------------|------------------------------|---------------|--|----------------|---------------|---------------|---------------------------------|----------------------|----------------------------------|----------------------------------|----------------------------------|
| | | Clor rezidual liber [mg/l] | Turbiditate [NTU] | Culoare | Gust | pH [unitati pH] | Conductivitate [μ S/cm] | Duritate [°G] | Subst. organice [mg O ₂ /l] | Nitriti [mg/l] | Amoniu [mg/l] | Azoati [mg/l] | *Bacterii coliforme [nr/100 ml] | *E. coli [nr/100 ml] | *Enterococintestinal [nr/100 ml] | *UFC 37°C/ml | *UFC 22°C/ml |
| CMA | | ≥0.1-≤0.5 | max5 | incolor | Acc cons | 5.6-9.5 | Max 2500 | min5 | max5 | ≥0.5 | ≥0.5 | ≥50 | 0 | 0 | 0 | nicio modificare anormala | nicio modificare anormala |

| | | | | | | | | | | | | | | | | |
|---------------------|------|------|-----|----------|---------------|------|------|------|---------|---------|------|---|---|---|---|---|
| Calan ON consumator | 0.51 | 1.19 | inc | Acc cons | 6.96 / 20.8°C | 86.8 | 2.08 | 0.77 | <0.0208 | <0.0141 | 1.96 | 0 | 0 | 0 | 0 | 0 |
| Calan OV Gradinita | 0.85 | 0.99 | inc | Acc cons | 6.52 / 20.4°C | 86.4 | 2.25 | 0.71 | <0.0208 | <0.0141 | 1.70 | 0 | 0 | 0 | 0 | 0 |
| Plopi nr 92 | 0.68 | 1.10 | inc | Acc cons | 6.54 / 20.3°C | 90.6 | 2.30 | 0.70 | <0.0208 | <0.0141 | 1.35 | 0 | 0 | 0 | 0 | 0 |
| Calanul Mic Gara | 0.51 | 1,08 | inc | Acc cons | 6.54 / 20.8°C | 92 | 2.28 | 0.92 | <0.0208 | <0.0141 | 2.00 | 0 | 0 | 0 | 0 | 0 |

Monitorizarea calitatii apei potabile luna februarie 2019

Sector DEVA – zona Dobra

| Punct de recoltare | Parametrii analizati | | | | | | | | | | | | | | | |
|--------------------|----------------------------|-------------------|---------|------|-----------------|------------------------------|---------------|--|----------------|---------------|---------------|---------------------------------|----------------------|-------------------------------------|--------------|--------------|
| | Clor rezidual liber [mg/l] | Turbiditate [NTU] | Culoare | Gust | pH [unitati pH] | Conductivitate [μ S/cm] | Duritate [°G] | Subst. organice [mg O ₂ /l] | Nitriti [mg/l] | Amoniu [mg/l] | Azoati [mg/l] | *Bacterii coliforme [nr/100 ml] | *E. coli [nr/100 ml] | *Enterococi intestinali [nr/100 ml] | *UFC 37°C/ml | *UFC 22°C/ml |

| C M A | | ≥0.1-≤0.5 | max5 | incolor | Acc cons | 5.6-9.5 | Max 2500 | min5 | max5 | ≥0.5 | ≥0.5 | ≥50 | 0 | 0 | 0 | nicio modifi care anorm ala | nicio modif icare anor mala anor mala |
|----------------------|---------------------|------------------|-------------|----------------|-----------------|------------------|---------------------|-------------|-------------|-------------|-------------|------------|----------|----------|----------|--|--|
| | Ilia gara | 0.28 | 2.28 | inc | Acc cons | 6.99 / 20.8°C | 230 | 7.20 | 0.77 | <0.0208 | <0.0141 | 1.08 | 0 | 0 | 0 | 0 | 0 |
| | Bar Gruber Dobra | 0.43 | 1.91 | inc | Acc cons | 6.80/ 19.8°C | 217 | 7.22 | 1.05 | <0.0208 | <0.0141 | 2.02 | 0 | 0 | 0 | 0 | 0 |

Monitorizarea calitatii apei potabile luna februarie 2019

Sector DEVA – zona Vetel

| | |
|-----------------|----------------------|
| Punct de | Parametrii analizati |
|-----------------|----------------------|

| | recoltare | Clor rezidual liber [mg/l] | Turbiditate [NTU] | Culoare | Gust | pH [unitati pH] | Conductivitate [μ S/cm] | Duritate [$^{\circ}$ G] | Subst. organice [mg O ₂ /l] | Nitriti [mg/l] | Amoniu [mg/l] | Azoati [mg/l] | *Bacterii coliforme [nr/100 ml] | *E. coli [nr/100 ml] | *Enterococi intestinali [nr/100 ml] | *UFC 37 ^o C/ml | *UFC 22 ^o C/ml |
|-------------|------------------|----------------------------|-------------------|---------|----------|--------------------------|------------------------------|--------------------------|--|----------------|---------------|---------------|---------------------------------|----------------------|-------------------------------------|----------------------------------|----------------------------------|
| CM A | | $\geq 0.1 - \leq 0.5$ | max5 | incolor | Acc cons | 5.6-9.5 | Max 2500 | min5 | max5 | ≥ 0.5 | ≥ 0.5 | ≥ 50 | 0 | 0 | 0 | nicio modificare anormala | nicio modificare anormala |
| | Bar Paula Vetel | 0.52 | 1.22 | inc | Acc cons | 6.59/19.8 ^o C | 90.5 | 2.77 | 0.71 | <0.0208 | <0.0141 | 2.05 | 0 | 0 | 0 | 0 | 0 |

Sector SIMERIA

Monitorizarea calitatii apei potabile luna februarie 2019

| | Punct de recoltare | Parametrii analizati | | | | | | | | | | | | | | | |
|------------|------------------------|----------------------------|-------------------|---------|----------|--------------------------|------------------------------|--------------------------|--|----------------|---------------|---------------|---------------------------------|----------------------|-------------------------------------|---------------------------|---------------------------|
| | | Clor rezidual liber [mg/l] | Turbiditate [NTU] | Culoare | Gust | pH [unitati pH] | Conductivitate [μ S/cm] | Duritate [$^{\circ}$ G] | Subst. organice [mg O ₂ /l] | Nitriti [mg/l] | Amoniu [mg/l] | Azoati [mg/l] | *Bacterii coliforme [nr/100 ml] | *E. coli [nr/100 ml] | *Enterococi intestinali [nr/100 ml] | *UFC 37 $^{\circ}$ C/ml | *UFC 22 $^{\circ}$ C/ml |
| CMA | | $\geq 0.1 - \leq 0.5$ | max5 | incolor | Acc cons | 5.6-9.5 | Max 2500 | min5 | max5 | ≥ 0.5 | ≥ 0.5 | ≥ 50 | 0 | 0 | 0 | nicio modificare anormala | nicio modificare anormala |
| | Carpinis nr 56 | 0.19 | 1.03 | inc | Acc cons | 6.52 / 20.6 $^{\circ}$ C | 82.6 | 0.78 | 3.15 | <0.0208 | <0.0141 | 1.89 | 0 | 0 | 0 | 0 | 0 |
| | Zona I Simeria Piata | 0.49 | 1.13 | inc | Acc cons | 6.62 / 20.9 $^{\circ}$ C | 86.2 | 0.72 | 2.80 | <0.0208 | <0.0141 | 1.61 | 0 | 0 | 0 | 0 | 0 |
| | Sântandrei, consumator | 0.67 | 1.08 | inc | Acc cons | 6.67 / 19.4 $^{\circ}$ C | 90.7 | 2.34 | 0.84 | <0.0208 | <0.0141 | 1.28 | 0 | 0 | 0 | 0 | 0 |

| | Punct de recoltare | Parametrii analizati | | | | | | | | | | | | | | | |
|------------|-------------------------|----------------------------|-------------------|---------|----------|----------------------------|------------------------------|--------------------------|--|----------------|---------------|---------------|---------------------------------|----------------------|-------------------------------------|---------------------------|---------------------------|
| | | Clor rezidual liber [mg/l] | Turbiditate [NTU] | Culoare | Gust | pH [unitati pH] | Conductivitate [μ S/cm] | Duritate [$^{\circ}$ G] | Subst. organice [mg O ₂ /l] | Nitriti [mg/l] | Amoniu [mg/l] | Azoati [mg/l] | *Bacterii coliforme [nr/100 ml] | *E. coli [nr/100 ml] | *Enterococi intestinali [nr/100 ml] | *UFC 37 $^{\circ}$ C/ml | *UFC 22 $^{\circ}$ C/ml |
| CMA | | $\geq 0.1 - \leq 0.5$ | max5 | incolor | Acc cons | 5.6-9.5 | Max 2500 | min5 | max5 | ≥ 0.5 | ≥ 0.5 | ≥ 50 | 0 | 0 | 0 | nicio modificare anormala | nicio modificare anormala |
| | Colegiul tehnic Geoagiu | 0.54 | 0.27 | inc | Acc cons | 7.34/ 20.0 $^{\circ}$ C | 785 | 20.18 | 0.59 | <0.0208 | <0.0141 | 2.98 | 0 | 0 | 0 | 0 | 0 |
| | Romosel consumator | 0.27 | 3.08 | inc | Acc cons | 6.60/ 20.1 $^{\circ}$ C | 101.9 | 2.58 | 1.27 | <0.0208 | <0.0141 | 2.36 | 0 | 0 | 0 | 0 | 0 |
| | Bozes consumator | 0.32 | 0.55 | inc | Acc cons | 7.19/ 19.9 $^{\circ}$ C | 500 | 15.46 | 0.64 | <0.0208 | <0.0141 | 4.17 | 0 | 0 | 0 | 0 | 0 |