

Monitorizarea calitatii apei potabile luna iunie 2019

Sector DEVA

Cod proba / Data prelevării	Punct de recoltare	Parametrii analizati														
		Clor rezidual liber [mg/l]	Turbiditate [NTU]	pH [unitati pH]	Conductivitate [µS/cm]	Duritate [°G]	Subst. organice [mgO ₂ /l]	Cloruri [mg/l]	Nitriti [mg/l]	Amoniu [mg/l]	Azotati [mg/l]	*Bacterii coliforme [nr/100 ml]	*E.coli [nr/100 ml]	*Enterococi intesti- nail [nr/100 ml]	*UFC 37°C/ml	*UFC 22°C/ml
46.06/ 04.06.'19	Liceul Transilvania	0.10	1.55	6.66/ 23.4°C	71.2	1.77	0.96	2.07	<0.0208	<0.0141	1.22	0	0	0	0	0
47.06/ 04.06.'19	Café Bar LEO	0.49	1.68	6.67/ 23.1°C	73.9	1.83	0.96	2.07	<0.0208	<0.0141	1.24	0	0	0	0	0
180.06/ 10.06.'19	Liceul Transilvania	0.14	1.07	6.70/ 23.1°C	76.5	1.77	1.04	3.79	<0.0208	0.0376	1.28	0	0	0	0	0
239.06/ 12.06.'19	Liceul Sportiv Cetate Deva	0.21	1.12	6.64/ 23.4°C	77.0	1.83	1.93	2.75	<0.0208	0.0376	1.28	0	0	0	0	0
242.06/ 12.06.'19	Pizzeria Casa Rustica	0.62	0.68	6.53/ 23.4°C	79.1	1.89	0.73	3.10	<0.0208	<0.0141	1.36	0	0	0	0	0
346.06/ 18.06.'19	Pizzeria Play Str Eminescu	0.42	0.88	6.67/ 23.4°C	76.0	1.95	0.58	2.75	<0.0208	<0.0141	1.45	0	0	0	0	0
348.06/ 18.06.'19	Penny Market Str Eminescu, nr 105	0.18	0.87	6.80/ 23.4°C	75.8	1.83	0.64	2.41	<0.0208	<0.0141	1.46	0	0	0	0	0
473.06/ 24.06.'19	Cofetaria Sicopan Str Zamfirescu	0.47	1.27	6.88/ 23.1°C	74.9	2.00	1.16	2.41	<0.0208	<0.0141	1.217	0	0	0	0	0
538.06/ 26.06.'19	Laborator Sicopan Santuhalm	0.58	0.76	6.79/ 23.4°C	75.5	1.95	0.64	2.75	<0.0208	<0.0141	1.26	0	0	0	0	0

Sector Deva - Certej

Cod proba / Data prelevării	Punct de recoltare	Parametrii analizati														
		Clor rezidual liber [mg/l]	Turbiditate [NTU]	pH [unitati pH]	Conductivitate [µS/cm]	Duritate [°G]	Subst. organice [mgO ₂ /l]	Cloruri [mg/l]	Nitriti [mg/l]	Amoniu [mg/l]	Azotati [mg/l]	*Bacterii coliforme [nr/100 ml]	*E. coli [nr/100 ml]	*Enterococi intestinali [nr/100 ml]	*UFC 37°C/ml	*UFC 22°C/ml
661.06/ 24.06.'19	Certej primarie	0.31	0.87	7.30/ 23.3°C	333	9.10	1.48	19.63	<0.0208	<0.0141	1.446	0	0	0	2	4

Sector Calan

Cod proba / Data prelevării	Punct de recoltare	Parametrii analizati														
		Clor rezidual liber [mg/l]	Turbiditate [NTU]	pH [unitati pH]	Conductivitate [µS/cm]	Duritate [°G]	Subst. organice [mgO ₂ /l]	Cloruri [mg/l]	Nitriti [mg/l]	Amoniu [mg/l]	Azotati [mg/l]	*Bacterii coliforme [nr/100 ml]	*E. coli [nr/100 ml]	*Enterococi intestinali [nr/100 ml]	*UFC 37°C/ml	*UFC 22°C/ml
68.06 / 04.06.'19	Calan ON Scoala Veche	0.25	2.39	6.58 / 21.9°C	72.1	1.77	0.58	2.07	<0.0208	<0.0141	2.59	0	0	0	0	0
506.06 / 25.06.'19	Calan ON Hala Piata	0.61	0.60	-	-	-	-	-	-	-	-	0	0	0	0	0
507.06 / 25.06.'19	Strei Sacel, nr 20	0.44	0.61	6.75 / 24.1°C	74.9	1.95	0.64	2.07	<0.0208	<0.0141	1.13	0	0	0	0	0
508.06 / 25.06.'19	Gantaga nr 8	0.25	1.24	6.91 / 24.0°C	75.2	2.00	0.83	2.41	<0.0208	<0.0141	1.10	0	0	0	0	0

Sector Geoagiu

Cod proba / Data prelevării	Punct de recoltare	Parametrii analizati														
		Clor rezidual liber [mg/l]	Turbiditate [NTU]	pH [unitati pH]	Conductivitate [µS/cm]	Duritate [°G]	Subst. organice [mgO ₂ /l]	Cloruri [mg/l]	Nitriti [mg/l]	Amoniu [mg/l]	Azotati [mg/l]	*Bacterii coliforme [nr/100 ml]	*E. coli [nr/100 ml]	*Enterococi intestinali [nr/100 ml]	*UFC 37°C/ml	*UFC 22°C/ml
256.06/12.06.'19	Liceul Agricol Geoagiu	0.41	0.38	7.31/23.4°C	781	19.73	0.80	22.72	<0.0208	<0.0141	3.11	0	0	0	0	0
540.06/26.06.'19	Hotel Agreement Geoagiu	0.35	0.25	7.21/23.7oC	799	21.50	0.51	25.83	-	-	-	0	0	0	0	0
543.06/26.06.'19	Bozes consumator	0.35	0.27	7.35/24.2oC	677	18.37	0.70	16.18	<0.0208	<0.0141	3.02	0	0	0	0	0

Sector Deva – Mintia

Cod proba / Data prelevării	Punct de recoltare	Parametrii analizati														
		Clor rezidual liber [mg/l]	Turbiditate [NTU]	pH [unitati pH]	Conductivitate [µS/cm]	Duritate [°G]	Subst. organice [mgO ₂ /l]	Cloruri [mg/l]	Nitriti [mg/l]	Amoniu [mg/l]	Azotati [mg/l]	*Bacterii coliforme [nr/100 ml]	*E. coli [nr/100 ml]	*Enterococi intestinali [nr/100 ml]	*UFC 37°C/ml	*UFC 22°C/ml
221.06 / 11.06.19	ABC Mintia	0.57	1.40	7.23 / 21.9°C	85.3	1.95	0.89	3.10	<0.0208	<0.0141	1.46	0	0	0	0	0

Sector Simeria

Cod proba / Data prelevării	Punct de recoltare	Parametrii analizati														
		Clor rezidual liber [mg/l]	Turbiditate [NTU]	pH [unitati pH]	Conductivitate [µS/cm]	Duritate [oG]	Subst. organice [mgO ₂ /l]	Cloruri [mg/l]	Nitriti [mg/l]	Amoniu [mg/l]	Azotati [mg/l]	*Bacterii coliforme [nr/100 ml]	*E.coli [nr/100 ml]	*Enterococi intestinali [nr/100 ml]	*UFC 37oC/ml	*UFC 22oC/ml
92.06/ 05.06.'19	Simeria I Piata centrala	0.17	1.62	6.57 / 19.9oC	76.1	2.46	1.14	2.75	<0.0208	<0.0141	-	0	0	0	0	0
384.06/ 19.06.'19	Petreni nr 71	0.25	0.46	6.59 / 23.2oC	76.2	1.95	0.65	2.75	<0.0208	<0.0141	1.41	0	0	0	0	0
534.06/ 26.06.'19	Uroi ABC	0.11	1.68	6.78 / 23.9oC	75.1	2.07	0.58	3.44	<0.0208	<0.0141	1.10	0	0	0	0	0

Sector Deva – Soimus

Cod proba / Data prelevării	Punct de recoltare	Parametrii analizati														
		Clor rezidual liber [mg/l]	Turbiditate [NTU]	pH [unitati pH]	Conductivitate [µS/cm]	Duritate [oG]	Subst. organice [mgO ₂ /l]	Cloruri [mg/l]	Nitriti [mg/l]	Amoniu [mg/l]	Azotati [mg/l]	*Bacterii coliforme [nr/100 ml]	*E.coli [nr/100 ml]	*Enterococi intestinali [nr/100 ml]	*UFC 37oC/ml	*UFC 22oC/ml
471.06 / 24.06.19	Chiscadaga ABC	0.16	1.87	7.48/ 23.3oC	85.7	2.07	0.58	3.79	<0.0208	<0.0141	1.163	0	0	0	0	0