

Monitorizare operationala Sector- **Hunedoara**-luna august 2022

Cod proba / Data prelevării	Punct de recoltare	Parametrii analizati															
		Clor rezidual liber / Total [mg/l]	Turbiditate [NTU]	pH [unitati pH]	Conductivitate [µS/cm]	Duritate [°G]	Subst. organice [mgO ₂ /l]	Cloruri [mg/l]	Nitriti [mg/l]	Amoniu [mg/l]	Azotati [mg/l]	*Bacterii coliforme [nr/100 ml]	*E. coli [nr/100 ml]	*Enterococi intestinali [nr/100 ml]	*UFC 37°C/ml	*UFC 22°C/ml	*Clostridium Perfringens
CMA		0.5	5	6.5-9.5	2500	min 5	5	250	0.5	0.5	50	0	0	0	**	**	0
23.08/ 2.08.2022	Statia Sanpetru	0,56/ 0,62	0,92	7,14/ 22,4°C	88,8	1,98	0,83	1,70	<0,0065	<0,0286	1,46	0	0	0	0	0	0
42.08/ 2.08.2022	Sediu Apa Prod Nr.8(DN=350mm)	0,36/ 0,38	0,77	6,85/ 22,7°C	90,3	2,24	0,79	2,05	<0,0065	<0,0286	2,43	0	0	0	0	0	0
150.08/ 9.08.2022	Gradinita nr.5(A.B.C)(Rezerv or 2*2500mc)	0,24/ 0,27	0,58	7,34/ 21,2°C	95,1	2,37	0,38	2,13	<0,0065	<0,0286	1,56	0	0	0	0	0	0
231.08/ 16.08.2022	Statia Sanpetru	0,71/ 0,78	0,37	7,13/ 22,4°C	95,1	2,39	0,64	2,41	<0,0065	<0,0286	1,83	0	0	0	0	0	0
251.08/ 16.08.2022	Gradinita O.T(bloc 138)(Φ350)	0,46/ 0,47	0,37	7,07/ 22,9°C	96,8	2,54	0,67	2,20	<0,0065	<0,0286	1,66	0	0	0	0	0	0
350.08/ 23.08.2022	Statia Sanpetru	0,50/ 0,52	2,02	7,03/ 22,0°C	85,0	2,05	1,28	4,68	<0,0065	<0,0286	2,09	0	0	0	0	0	0
371.08/ 23.08.2022	Scoala nr.5-cisnea (Φ350)	0,21/ 0,24	0,44	7,14/ 20,1°C	91,2	2,21	0,38	6,10	<0,0065	<0,0286	2,10	0	0	0	0	0	0

372.08/ 23.08.2022	Penny Market(rezervor 2*1500mc)	0,18/ 0,19	0,40	7,29/ 20,5°C	98,0	2,91	0,60	2,05	<0,0065	<0,0286	1,53	0	0	0	0	0	0
469.08/ 30.08.2022	Statia Sanpetru	0,52/ 0,55	0,44	7,16/ 22,2°C	75,9	1,92	0,76	0,71	<0,0065	<0,0286	1,46	0	0	0	0	0	0
488.08/ 30.08.2022	Liceul Nr.3(rezervor 2*5000mc)	0,25/ 0,29	0,35	6,92/ 22,7°C	76,2	1,85	0,73	1,84	<0,0065	<0,0286	1,37	0	0	0	0	0	0

Monitorizare operationala **Cincis-Cerna** –luna august 2022

Cod proba / Data prelevării	Punct de recoltare	Parametrii analizati															
		Clor rezidual liber / Total [mg/l]	Turbiditate [NTU]	pH [unitati pH]	Conductivitate [µS/cm]	Duritate [°G]	Subst. organice [mgO ₂ /l]	Cloruri [mg/l]	Nitriti [mg/l]	Amoniu [mg/l]	Azotati [mg/l]	*Bacterii coliforme [nr/100 ml]	*E. coli [nr/100 ml]	*Enterococi intestinali [nr/100 ml]	*UFC 37°C/ml	*UFC 22°C/ml	* Clostridium Perfringers
CMA		0.5	5	6.5-9.5	2500	min 5	5	250	0.5	0.5	50	0	0	0	**	**	0
29.08/ 2.08.2022	Scoala Cincis(A.B.C) (rezervor Cincis-Cerna)	0,22/ 0,25	0,72	7,12/ 22,7°C	91,6	2,25	0,76	1,42	<0,0065	<0,0286	1,68	0	0	0	0	0	0
30.08/ 2.08.2022	STA Cincis- Cerna	0,64/ 0,72	0,63	7,06/ 22,8°C	90,3	2,37	0,83	1,70	<0,0065	<0,0286	1,54	0	0	0	0	0	0
34.08/ 2.08.2022	Scoala Teliuc(Primar ie)(Rezervor Teliucu inferior)	0,30/ 0,36	0,99	7,14/ 23,0°C	90,2	2,41	0,76	1,42	<0,0065	<0,0286	1,60	0	0	0	0	0	0

Monitorizare operationala **Cristur** –luna septembrie 2022

Cod proba / Data prelevării	Punct de recoltare	Parametrii analizati															
		Clor rezidual liber / Total/ Liber [mg/l]	Turbiditate [NTU]	pH [unitati pH]	Conductivitate [µS/cm]	Duritate [°G]	Subst. organice [mgO ₂ /l]	Cloruri [mg/l]	Nitriti [mg/l]	Amoniu [mg/l]	Azotati [mg/l]	*Bacterii coliforme [nr/100 ml]	*E. coli [nr/100 ml]	*Enterococi intestinali [nr/100 ml]	*UFC 37°C/ml	*UFC 22°C/ml	* Clostridium Perfingers
CMA		0.5	5	6.5-9.5	2500	min 5	5	250	0.5	0.5	50	0	0	0	**	**	0
199.09/ 13.09.2022	Scoala Romana- Cristur	0,27/ 0,30	1,20	7,52/ 21,3°C	60,4	1,66	0,38	1,13	<0,0065	<0,0286	0,82	0	0	0	0	0	0

Monitorizare operationala- **Sector Calan** -luna august 2022

Cod proba / Data prelevării	Punct de recoltare	Parametrii analizati															
		Clor rezidual liber / Total [mg/l]	Turbiditate [NTU]	pH [unitati pH]	Conductivitate [µS/cm]	Duritate [°G]	Subst. organice [mgO ₂ /l]	Cloruri [mg/l]	Nitriti [mg/l]	Amoniu [mg/l]	Azotati [mg/l]	*Bacterii coliforme [nr/100 ml]	*E. coli [nr/100 ml]	*Enterococi intestinali [nr/100 ml]	*UFC 37°C/ml	*UFC 22°C/ml	* Clostridium Perfringers
CMA		0.5	5	6.5-9.5	2500	min 5	5	250	0.5	0.5	50	0	0	0	**	**	0
159.08/ 9.08.2022	Calan O.N- Hala Piata	0,16/ 0,21	0,42	7,29/ 22,9°C	59,4	1,44	0,51	2,13	<0,0065	<0,0286	0,61	0	0	0	0	0	0
160.08/ 9.08.2022	Bretea Romana- Primarie	0,54/ 0,60	0,40	7,08/ 22,7°C	58,9	1,40	0,38	1,56	0,0105	<0,0286	0,42	0	0	0	0	0	0
161.08/ 9.08.2022	Maceu nr.128- magazin	0,27/ 0,29	0,48	6,99/ 22,3°C	58,5	1,49	0,32	1,84	<0,0065	<0,0286	0,43	0	0	0	0	0	0

Monitorizare operationala Sector Simeria –luna august 2022

Cod proba / Data prelevării	Punct de recoltare	Parametrii analizati															
		Clor rezidual liber / Total/ Liber [mg/l]	Turbiditate [NTU]	pH [unitati pH]	Conductivitate [µS/cm]	Duritate [°G]	Subst. organice [mgO ₂ /l]	Cloruri [mg/l]	Nitriti [mg/l]	Amoniu [mg/l]	Azotati [mg/l]	*Bacterii coliforme [nr/100 ml]	*E. coli [nr/100 ml]	*Enterococi intestinali [nr/100 ml]	*UFC 37°C/ml	*UFC 22°C/ml	* Clostridium Perfringers
CMA		0.5	5	6.5-9.5	2500	min 5	5	250	0.5	0.5	50	0	0	0	**	**	0
512.08/ 31.08.2022	Simeria zona II-Statie OMV	0,18/ 0,26	0,58	7,32/ 23,0 °C	59,8	1,60	0,51	1,56	<0,0065	<0,0286	0,77	0	0	0	0	0	0
513.08/ 31.08.2022	Uroi-mgazin First Hand	0,23/ 0,25	0,61	6,79/ 22,9 °C	59,2	1,64	0,89	1,70	<0,0065	<0,0286	0,75	0	0	0	0	0	0

Monitorizare operationala Sector Geogiu-luna august 2022

Cod proba / Data prelevării	Punct de recoltare	Parametrii analizati															
		Clor rezidual liber / Total [mg/l]	Turbiditate [NTU]	pH [unitati pH]	Conductivitate [µS/cm]	Duritate [°G]	Subst. organice [mgO ₂ /l]	Cloruri [mg/l]	Nitriti [mg/l]	Amoniu [mg/l]	Azotati [mg/l]	*Bacterii coliforme	*E. coli [nr/100 ml]	*Enterococi intestinali [nr/100 ml]	*UFC 37°C/ml	*UFC 22°C/ml	*Clostridium Perfringens
CMA		0.5	5	6.5-9.5	2500	min 5	5	250	0.5	0.5	50	0	0	0	**	**	0
271.08/ 17.08.2022	STA Folorat	0,77/ 0,82	0,30	7,36/ 23,0°C	938	25,01	0,32	30,67	<0,0065	<0,0286	8,67	0	0	0	0	0	-
272.08/ 17.08.2022	STA Bacaia- Bozes	0,68/ 0,68	0,15	7,32/ 22,7°C	523	13,78	0,19	4,82	<0,0065	<0,0286	3,63	0	0	0	0	0	-
275.08/ 17.08.2022	STA Romos	0,60/ 0,68	0,46	7,09/ 23,0°C	171,7	3,79	1,28	3,97	<0,0065	<0,0286	1,07	0	0	0	0	0	0
518.08/ 31.08.2022	Hotel Ceres(rez 1000mc)	0,47/ 0,49	0,25	7,31/ 22,8°C	932	23,20	0,25	30,24	<0,0065	<0,0286	6,34	0	0	0	0	0	-
521.08/ 31.08.2022	A.B.C PASCU- Romosel	0,21/ 0,31	0,47	7,34/ 23,0°C	180,9	4,29	0,83	6,81	<0,0065	<0,0286	1,08	0	0	0	0	0	0