

**Valori medii saptamanale ale parametrilor de potabilitate (01.05 – 07.05.2023)**

Punct de recoltare	Parametrii analizati															
	Clor rezidual liber [mg/l]	Turbiditate [NTU]	pH [unitati pH]	Conductivitate [ $\mu$ S/cm]	Duritate [ $^{\circ}$ G]	Subst. organice [mgO <sub>2</sub> /l]	Cloruri [mg/l]	Nitriti [mg/l]	Amoniu [mg/l]	Azotati [mg/l]	Bacterii coliforme [nr/100 ml]	E. coli [nr/100 ml]	Enterococi intestinali [nr/100 ml]	UFC 37°C/ml	UFC 22°C/ml	*Clostridium Perfringens
<b>CMA (Ordonanta 7/2023)</b>	<b>0.1-0.5</b>	<b>acc. cons</b>	<b>6.5-9.5</b>	<b>2500</b>	<b>min 5</b>	<b>5</b>	<b>250</b>	<b>0.5</b>	<b>0.5</b>	<b>50</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>**</b>	<b>**</b>	<b>0</b>
Hateg	0,35	0,66	7,04/ 20,0°C	85,95	2,18	0,69	1,73	<0.0058	<0.0222	1,45	0	0	0	0	0	0
Hunedoara	0,35	0,40	6,93/ 20,2°C	72,1	1,89	0,49	1,51	<0.0065	<0.0286	1,23	0	0	0	0	0	0
Calan	0,41	0,67	6,86/ 20,4°C	87,7	2,13	3,52	2,98	<0.0065	<0.0286	-	0	0	0	0	0	0
Simeria	0,24	0,66	6,83/ 20,7°C	98,8	2,58	0,96	3,55	<0.0065	<0.0286	1,59	0	0	0	0	0	0
Geoagiu	0,56	0,19	-	-	-	-	-	-	-	-	0	0	0	0	0	0
Deva	0.34	0.73	7,19/ 19,4°C	95.6	2.06	0.78	2.36	<0.0062	<0.0142	1.76	0	0	0	0	0	0
Brad	0.39	0.33	7,37/ 19,3°C	332	9.16	0.64	5.39	<0.0062	<0.0142	0.65	0	0	0	0	0	0

Nota:

- \*\* Nici o modificare anormala.
- CMA – concentratie maxima admisa conf Ordonanta 7/2023