

**Valori medii saptamanale ale parametrilor de potabilitate (08.05 – 14.05.2023)**

Punct de recoltare	Parametrii analizati															
	Clor rezidual liber [mg/l]	Turbiditate [NTU]	pH [unitati pH]	Conductivitate [μS/cm]	Duritate [°G]	Subst. organice [mgO <sub>2</sub> /l]	Cloruri [mg/l]	Nitriti [mg/l]	Amoniu [mg/l]	Azotati [mg/l]	Bacterii coliforme [nr/100 ml]	E. coli [nr/100 ml]	Enterococi intestinali [nr/100 ml]	UFC 37°C/ml	UFC 22°C/ml	*Clostridium Perfringens
<b>CMA (Ordonanta 7/2023)</b>	<b>0.1-0.5</b>	<b>acc. cons</b>	<b>6.5-9.5</b>	<b>2500</b>	<b>min 5</b>	<b>5</b>	<b>250</b>	<b>0.5</b>	<b>0.5</b>	<b>50</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>**</b>	<b>**</b>	<b>0</b>
Hateg	0,52	0,57	7,14/ 19,5°C	76,24	2,06	0,69	<2,00	<0.0058	<0.0222	1,38	0	0	0	0	0	0
Hunedoara	0,37	0,55	6,79/ 19,9°C	61,5	1,71	0,50	1,62	<0.0065	<0.0286	1,21	0	0	0	0	0	0
Calan	0,31	1,43	7,15/ 20,6°C	83,1	1,99	0,35	1,98	<0.0065	<0.0286	1,16	0	0	0	0	0	0
Simeria	0,34	0,46	-	-	-	-	-	-	-	-	0	0	0	0	0	0
Geoagiu	0,63	0,42	7,29/ 20,8°C	884	22,73	0,25	29,25	<0.0065	<0.0286	5,49	0	0	0	0	0	0
Deva	0.31	0.68	7,24/ 19,6°C	87.3	1.97	0.71	2.21	<0.0062	<0.0142	-	0	0	0	0	0	0
Brad	0.41	0.67	7,67/ 19,4°C	356	9.61	0.51	6.06	<0.0062	<0.0142	-	0	0	0	0	0	0

Nota:

- \*\* Nici o modificare anormala.
- CMA – concentratie maxima admisa conf Ordonanta 7/2023