

**Valori medii saptamanale ale parametrilor de potabilitate (15.05 – 21.05.2023)**

Punct de recoltare	Parametrii analizati															
	Clor rezidual liber [mg/l]	Turbiditate [NTU]	pH [unitati pH]	Conductivitate [ $\mu$ S/cm]	Duritate [ $^{\circ}$ G]	Subst. organice [mgO <sub>2</sub> /l]	Cloruri [mg/l]	Nitriti [mg/l]	Amoniu [mg/l]	Azotati [mg/l]	Bacterii coliforme [nr/100 ml]	E. coli [nr/100 ml]	Enterococi intestinali [nr/100 ml]	UFC 37°C/ml	UFC 22°C/ml	*Clostridium Perfringens
<b>CMA (Ordonanta 7/2023)</b>	<b>0.1-0.5</b>	<b>acc. cons</b>	<b>6.5-9.5</b>	<b>2500</b>	<b>min 5</b>	<b>5</b>	<b>250</b>	<b>0.5</b>	<b>0.5</b>	<b>50</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>**</b>	<b>**</b>	<b>0</b>
Hateg	0,58	0,51	6,97/ 19,0°C	70,02	1,89	0,68	<2,00	<0.0058	<0.0222	1,26	0	0	0	0	0	0
Hunedoara	0,36	0,74	6,75/ 20,1°C	59,83	1,69	0,56	1,66	<0.0065	<0.0286	1,17	0	0	0	0	0	0
Calan	0,41	0,48	-	-	-	-	-	-	-	-	0	0	0	0	0	0
Simeria	0,49	0,37	-	-	-	-	-	-	-	-	0	0	0	0	0	0
Geoagiu	0,59	0,16	6,86/ 20,0°C	875	21,65	0,12	29,32	<0.0065	<0.0286	5,93	0	0	0	0	0	0
Deva	0,27	0,64	7,12/ 19,9°C	75,82	1,87	0,65	-	<0.0062	<0.0142	-	0	0	0	0	0	0
Brad	0,44	0,46	7,96/ 19,3°C	363	10,19	0,58	6,40	<0.0062	<0.0142	0,85	0	0	0	0	0	0

Nota:

- \*\* Nici o modificare anormala.
- CMA – concentratie maxima admisa conf Ordonanta 7/2023