

Valori medii saptamanale ale parametrilor de potabilitate (05.06 – 11.06.2023)

Punct de recoltare	Parametrii analizati														
	Clor rezidual liber [mg/l]	Turbiditate [NTU]	pH [unitati pH]	Conductivitate [μS/cm]	Duritate [°G]	Subst. organice [mgO ₂ /l]	Cloruri [mg/l]	Nitriti [mg/l]	Amoniu [mg/l]	Bacterii coliforme [nr/100 ml]	E. coli [nr/100 ml]	Enterococi intestinali [nr/100 ml]	UFC 37°C/ml	UFC 22°C/ml	Clostridium Perfringens
CMA (Ordonanta 7/2023)	0.1-0.5	acc. cons	6.5-9.5	2500	min 5	5	250	0.5	0.5	0	0	0	**	**	0
Hateg	0,43	0,87	7,19/ 21,2°C	57,43	1,77	0,71	<2,00	<0.0058	<0.0222	0	0	0	0	0	0
Hunedoara	0,35	0,74	7,10/ 21,02°C	55,23	1,45	0,47	1,56	<0.0065	<0.0286	0	0	0	0	0	0
Calan	0,27	0,60	7,26/ 20,7°C	59,1	1,53	0,38	1,96	<0.0065	<0.0286	0	0	0	0	0	0
Simeria	0,20	0,75	7,29/ 21,0°C	71,30	1,80	0,25	1,82	<0.0065	<0.0286	0	0	0	0	0	0
Geoagiu	0,36	0,23	7,48/ 21,4°C	892	21,65	0,25	27,41	<0.0065	<0.0286	0	0	0	0	0	0
Deva	0,44	0,86	7,18/ 20,3°C	63,2	1,59	0,82	2,86	<0.0062	<0.0142	0	0	0	0	0	0
Brad	0,34	0,20	7,18/ 20,5°C	403	10,30	1,0	11,62	<0.0062	<0.0142	0	0	0	0	0	0

Nota:

- ** Nici o modificare anormala.
- CMA – concentratie maxima admisa conf Ordonanta 7/2023