

**Valori medii saptamanale ale parametrilor de potabilitate (29.05 – 04.06.2023)**

Punct de recoltare	Parametrii analizati														
	Clor rezidual liber [mg/l]	Turbiditate [NTU]	pH [unitati pH]	Conductivitate [μS/cm]	Duritate [°G]	Subst. organice [mgO <sub>2</sub> /l]	Cloruri [mg/l]	Nitriti [mg/l]	Amoniu [mg/l]	Bacterii coliforme [nr/100 ml]	E. coli [nr/100 ml]	Enterococi intestinali [nr/100 ml]	UFC 37°C/ml	UFC 22°C/ml	Clostridium Perfringens
<b>CMA (Ordonanta 7/2023)</b>	<b>0.1-0.5</b>	<b>acc. cons</b>	<b>6.5-9.5</b>	<b>2500</b>	<b>min 5</b>	<b>5</b>	<b>250</b>	<b>0.5</b>	<b>0.5</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>**</b>	<b>**</b>	<b>0</b>
Hateg	0,42	0,57	7,15/ 20,2°C	62,06	1,59	0,64	<2,00	<0.0058	<0.0222	0	0	0	0	0	0
Hunedoara	0,39	0,89	7,02/ 20,8°C	56,40	1,45	0,44	1,68	<0.0065	<0.0286	0	0	0	0	0	0
Simeria	0,28	0,74	7,36/ 21,0°C	75,10	1,75	0,38	1,68	<0.0065	<0.0286	0	0	0	0	0	0
Geoagiu	0,34	0,23	7,32/ 20,6°C	881	22,21	0,25	25,86	<0.0065	<0.0286	0	0	0	0	0	0
Deva	0,29	0,64	7,28/ 19,9°C	68,20	1,65	0,69	2,22	<0.0062	<0.0142	0	0	0	0	0	0
Brad	0,33	0,34	7,27/ 20,5°C	355	9,34	1,26	7,07	<0.0062	<0.0142	0	0	0	0	0	0

Nota:

- \*\* Nici o modificare anormala.
- CMA – concentratie maxima admisa conf Ordonanta 7/2023