

Valori medii saptamanale ale parametrilor de potabilitate (03.07 – 09.07.2023)

Punct de recoltare	Parametrii analizati														
	Clor rezidual liber [mg/l]	Turbiditate [NTU]	pH [unitati pH]	Conductivitate [μ S/cm]	Duritate [$^{\circ}$ G]	Subst. organice [mgO ₂ /l]	Cloruri [mg/l]	Nitriti [mg/l]	Amoniu [mg/l]	Bacterii coliforme [nr/100 ml]	E. coli [nr/100 ml]	Enterococi intestinali [nr/100 ml]	UFC 37 $^{\circ}$ C/ml	UFC 22 $^{\circ}$ C/ml	Clostridium Perfringens
CMA (Ordonanta 7/2023)	0.1-0.5	acc. cons	6.5-9.5	2500	min 5	5	250	0.5	0.5	0	0	0	**	**	0
Hateg	0,31	0,57	7,1/ 21,5 $^{\circ}$ C	53,37	1,40	0,65	<2,00	<0.0058	<0.0222	0	0	0	0	0	0
Hunedoara	0,38	0,86	7,28/ 22,0 $^{\circ}$ C	68,61	1,48	0,79	1,61	<0.0065	<0.0286	0	0	0	0	0	0
Calan	0,25	0,79	7,20/ 22,5 $^{\circ}$ C	59,6	1,44	0,97	1,61	<0.0065	<0.0286	0	0	0	0	0	0
Simeria	0,21	0,66	7,27/ 21,9 $^{\circ}$ C	58,4	1,39	0,57	1,54	<0.0065	<0.0286	0	0	0	0	0	0
Geoagiu	0,45	0,61	7,62/ 22,6 $^{\circ}$ C	899	22,21	0,44	28,11	<0.0065	<0.0286	0	0	0	0	0	0
Deva	0.24	1.21	7,20/ 21,5 $^{\circ}$ C	56.5	1.50	0.80	2.02	<0.0062	<0.0142	0	0	0	0	0	0
Brad	0.30	0.48	7,62/ 22,4 $^{\circ}$ C	372	9.79	1.26	6.74	<0.0062	<0.0142	0	0	0	0	0	0

Nota:

- ** Nici o modificare anormala.
- CMA – concentratie maxima admisa conf Ordonanta 7/2023