

**Valori medii saptamanale ale parametrilor de potabilitate (10.07 – 16.07.2023)**

Punct de recoltare	Parametrii analizati														
	Clor rezidual liber [mg/l]	Turbiditate [NTU]	pH [unitati pH]	Conductivitate [ $\mu$ S/cm]	Duritate [ $^{\circ}$ G]	Subst. organice [mgO <sub>2</sub> /l]	Cloruri [mg/l]	Nitriti [mg/l]	Amoniu [mg/l]	Bacterii coliforme [nr/100 ml]	E. coli [nr/100 ml]	Enterococi intestinali [nr/100 ml]	UFC 37°C/ml	UFC 22°C/ml	Clostridium Perfringens
<b>CMA (Ordonanta 7/2023)</b>	<b>0.1-0.5</b>	<b>acc. cons</b>	<b>6.5-9.5</b>	<b>2500</b>	<b>min 5</b>	<b>5</b>	<b>250</b>	<b>0.5</b>	<b>0.5</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>**</b>	<b>**</b>	<b>0</b>
Hateg	0,43	0,59	7,1/ 21,5°C	52,96	1,52	0,74	<2,00	<0.0058	<0.0222	0	0	0	0	0	0
Hunedoara	0,39	0,69	7,12/ 22,38°C	70,63	1,69	0,74	1,82	<0.0065	<0.0286	0	0	0	0	0	0
Calan	0,13	0,48	7,28/ 22,7°C	57,0	1,41	0,38	1,40	<0.0065	<0.0286	0	0	0	0	0	0
Simeria	0,13	0,47	7,27/ 22,7°C	60,9	1,25	0,83	1,40	<0.0065	<0.0286	0	0	0	0	0	0
Geoagiu	0,43	0,14	7,28/ 22,5°C	887	19,29	0,32	25,16	<0.0065	<0.0286	0	0	0	0	0	0
Deva	0.26	0.52	7,14/ 22,5°C	56.2	1.56	0.82	2.52	<0.0062	<0.0142	0	0	0	0	0	0
Brad	0.41	0.49	7,92/ 22,7°C	393	11.18	0.91	6.74	<0.0062	<0.0142	0	0	0	0	0	0

Nota:

- \*\* Nici o modificare anormala.
- CMA – concentratie maxima admisa conf Ordonanta 7/2023