

Valori medii saptamanale ale parametrilor de potabilitate (19.06 – 25.06.2023)

Punct de recoltare	Parametrii analizati														
	Clor rezidual liber [mg/l]	Turbiditate [NTU]	pH [unitati pH]	Conductivitate [μS/cm]	Duritate [°G]	Subst. organice [mgO ₂ /l]	Cloruri [mg/l]	Nitriti [mg/l]	Amoniu [mg/l]	Bacterii coliforme [nr/100 ml]	E. coli [nr/100 ml]	Enterococi intestinali [nr/100 ml]	UFC 37°C/ml	UFC 22°C/ml	Clostridium Perfringens
CMA (Ordonanta 7/2023)	0.1-0.5	acc. cons	6.5-9.5	2500	min 5	5	250	0.5	0.5	0	0	0	**	**	0
Hateg	0,31	0,95	7,1/ 21,0°C	54,25	1,58	0,70	<2,00	<0.0058	<0.0222	0	0	0	0	0	0
Hunedoara	0,40	1,05	7,16/ 21,15°C	58,96	1,50	1,08	2,00	<0.0065	<0.0286	0	0	0	0	0	0
Calan	0,22	1,48	7,07/ 22,0°C	57,4	1,51	0,44	1,82	<0.0065	<0.0286	0	0	0	0	0	0
Simeria	0,12	0,94	7,34/ 21,9°C	61,5	1,46	1,31	1,40	<0.0065	<0.0286	0	0	0	0	0	0
Geoagiu	0,45	0,17	7,49/ 21,8°C	874	19,86	0,62	23,61	<0.0065	<0.0286	0	0	0	0	0	0
Deva	0,27	0,73	7,13/ 20,5°C	56,4	1,55	0,60	2,36	<0.0062	<0.0142	0	0	0	0	0	0
Brad	0,28	0,30	7,20/ 21,0°C	316	8,88	0,93	3,03	<0.0062	<0.0142	0	0	0	0	0	0

Nota:

- ** Nici o modificare anormala.
- CMA – concentratie maxima admisa conf Ordonanta 7/2023