

Valori medii saptamanale ale parametrilor de potabilitate (26.06 – 02.07.2023)

| Punct de recoltare | Parametrii analizati | | | | | | | | | | | | | | |
|-----------------------------------|-------------------------------|----------------------|--------------------|---------------------------|------------------|--|-------------------|-------------------|------------------|-----------------------------------|------------------------|--|-------------|-------------|----------------------------|
| | Clor rezidual liber [mg/l] | Turbiditate [NTU] | pH [unitati pH] | Conductivitate [μS/cm] | Duritate [°G] | Subst. organice [mgO ₂ /l] | Cloruri [mg/l] | Nitriti [mg/l] | Amoniu [mg/l] | Bacterii coliforme [nr/100 ml] | E. coli [nr/100 ml] | Enterococi intestinali [nr/100 ml] | UFC 37°C/ml | UFC 22°C/ml | Clostridium Perfringens |
| CMA (Ordonanta 7/2023) | 0.1-0.5 | acc. cons | 6.5-9.5 | 2500 | min 5 | 5 | 250 | 0.5 | 0.5 | 0 | 0 | 0 | ** | ** | 0 |
| Hateg | 0,33 | 0,83 | 7,01/ 20,5°C | 55,11 | 1,41 | 0,70 | <2,00 | <0.0058 | <0.0222 | 0 | 0 | 0 | 0 | 0 | 0 |
| Hunedoara | 0,36 | 1,08 | 7,37/ 21,9°C | 65,83 | 1,55 | 0,84 | 1,58 | <0.0065 | <0.0286 | 0 | 0 | 0 | 0 | 0 | 0 |
| Calan | 0,27 | 1,84 | 7,27/ 22,3°C | 58,1 | 1,44 | 1,53 | 1,54 | <0.0065 | <0.0286 | 0 | 0 | 0 | 0 | 0 | 0 |
| Simeria | 0,45 | 1,97 | 7,80/ 21,8°C | 72,4 | 1,73 | 0,76 | 3,23 | <0.0065 | <0.0286 | 0 | 0 | 0 | 0 | 0 | 0 |
| Geoagiu | 0,40 | 0,16 | 7,45/ 21,9°C | 954 | 21,94 | 0,32 | 32,05 | <0.0065 | <0.0286 | 0 | 0 | 0 | 0 | 0 | 0 |
| Deva | 0.39 | 1.08 | 7,13/ 20,5°C | 56.1 | 1.56 | 0.85 | 2.69 | <0.0062 | <0.0142 | 0 | 0 | 0 | 0 | 0 | 0 |
| Brad | 0.37 | 0.44 | 7,17/ 20,3°C | 410 | 10.14 | 0.60 | 10.78 | <0.0062 | <0.0142 | 0 | 0 | 0 | 0 | 0 | 0 |

Nota:

- ** Nici o modificare anormala.
- CMA – concentratie maxima admisa conf Ordonanta 7/2023