

Valori medii saptamanale ale parametrilor de potabilitate (02.10 – 08.10.2023)

Punct de recoltare	Parametrii analizati														
	Clor rezidual liber [mg/l]	Turbiditate [NTU]	pH [unitati pH]	Conductivitate [μS/cm]	Duritate [°G]	Subst. organice [mgO ₂ /l]	Cloruri [mg/l]	Nitriti [mg/l]	Amoniu [mg/l]	Bacterii coliforme [nr/100 ml]	E. coli [nr/100 ml]	Enterococi intestinali [nr/100 ml]	UFC 37°C/ml	UFC 22°C/ml	Clostridium Perfringens
CMA (Ordonanta 7/2023)	0.1-0.5	acc. cons	6.5-9.5	2500	min 5	5	250	0.5	0.5	0	0	0	**	**	0
Hateg	0,53	0,39	7,20/ 20,4°C	61,90	1,54	0,71	<2,00	<0.0058	<0.0222	0	0	0	0	0	0
Hunedoara	0,40	0,84	7,36/ 20,98°C	66,90	1,94	0,58	1,87	<0.0065	<0.0286	0	0	0	0	0	0
Calan	0,28	0,39	7,48/ 21,0°C	69,7	1,96	0,89	2,10	<0.0065	<0.0286	0	0	0	0	0	0
Simeria	0,20	0,27	7,53/ 20,9°C	71,3	2,11	1,26	2,81	<0.0065	<0.0286	0	0	0	0	0	0
Geoagiu	0,38	0,13	7,65/ 20,4°C	878	19,54	0,54	28,11	<0.0065	<0.0286	0	0	0	0	0	0
Deva	0.20	0.57	7,05 / 20.8°C	67.4	1.69	0.82	2.70	<0.0062	<0.0142	0	0	0	0	0	0
Brad	0.28	0.20	7,90/ 20,9°C	398	10.82	0.80	7.07	<0.0062	<0.0142	0	0	0	0	0	0

Nota:

- ** Nici o modificare anormala.
- CMA – concentratie maxima admisa conf Ordonanta 7/2023