

Valori medii saptamanale ale parametrilor de potabilitate (11.09 – 17.09.2023)

Punct de recoltare	Parametrii analizati														
	Clor rezidual liber [mg/l]	Turbiditate [NTU]	pH [unitati pH]	Conductivitate [μS/cm]	Duritate [°G]	Subst. organice [mgO ₂ /l]	Cloruri [mg/l]	Nitriti [mg/l]	Amoniu [mg/l]	Bacterii coliforme [nr/100 ml]	E. coli [nr/100 ml]	Enterococi intestinali [nr/100 ml]	UFC 37°C/ml	UFC 22°C/ml	Clostridium Perfringens
CMA (Ordonanta 7/2023)	0.1-0.5	acc. cons	6.5-9.5	2500	min 5	5	250	0.5	0.5	0	0	0	**	**	0
Hateg	0,50	0,46	7,00 / 22,0°C	61,34	1,41	0,67	<2,00	<0.0058	<0.0222	0	0	0	0	0	0
Hunedoara	0,42	0,63	7,31 / 22,45°C	91,96	2,26	0,72	1,77	<0.0065	<0.0286	0	0	0	0	0	0
Calan	0,30	0,30	7,01 / 23,0°C	65,8	1,61	1,02	1,26	<0.0065	<0.0286	0	0	0	0	0	0
Simeria	0,15	0,43	7,09 / 22,7°C	64,9	1,50	1,02	1,54	<0.0065	<0.0286	0	0	0	0	0	0
Geoagiu	0,46	0,15	7,37 / 23,0°C	943	23,58	0,96	27,13	<0.0065	<0.0286	0	0	0	0	0	0
Deva	0.24	0.44	7,11 / 22.3°C	65.7	1.68	0.52	3.37	<0.0062	<0.0142	0	0	0	0	0	0
Brad	0.31	0.58	7,27/ 22.4°C	402	11.27	0.91	8.42	<0.0062	<0.0142	0	0	0	0	0	0

Nota:

- ** Nici o modificare anormala.
- CMA – concentratie maxima admisa conf Ordonanta 7/2023