

Valori medii saptamanale ale parametrilor de potabilitate (14.08 – 20.08.2023)

Punct de recoltare	Parametrii analizati														
	Clor rezidual liber [mg/l]	Turbiditate [NTU]	pH [unitati pH]	Conductivitate [μS/cm]	Duritate [°G]	Subst. organice [mgO ₂ /l]	Cloruri [mg/l]	Nitriti [mg/l]	Amoniu [mg/l]	Bacterii coliforme [nr/100 ml]	E. coli [nr/100 ml]	Enterococi intestinali [nr/100 ml]	UFC 37°C/ml	UFC 22°C/ml	Clostridium Perfringens
CMA (Ordonanta 7/2023)	0.1-0.5	acc. cons	6.5-9.5	2500	min 5	5	250	0.5	0.5	0	0	0	**	**	0
Hateg	0,32	0,32	7,00/ 22,6°C	56,60	1,39	0,70	<2,00	<0.0058	<0.0222	0	0	0	0	0	0
Hunedoara	0,39	0,63	7,32/ 22,59°C	88,18	2,11	0,68	1,89	<0.0065	<0.0286	0	0	0	0	0	0
Calan	0,22	0,34	7,15/ 22,8°C	60,3	1,54	0,51	1,82	<0.0065	<0.0286	0	0	0	0	0	0
Simeria	0,14	0,40	7,05/ 23,0°C	58,8	1,45	0,38	2,10	<0.0065	<0.0286	0	0	0	0	0	0
Geoagiu	0,40	0,24	7,29/ 22,8°C	916	16,42	0,64	22,77	<0.0065	<0.0286	0	0	0	0	0	0
Deva	0,28	0,39	7,05/ 22,6°C	56,3	1,51	0,77	2,69	<0.0062	<0.0142	0	0	0	0	0	0
Brad	0,29	0,48	7,86/ 22,3°C	400	11,39	0,86	6,74	<0.0062	<0.0142	0	0	0	0	0	0

Nota:

- ** Nici o modificare anormala.
- CMA – concentratie maxima admisa conf Ordonanta 7/2023