

Valori medii saptamanale ale parametrilor de potabilitate (17.07 – 23.07.2023)

Punct de recoltare	Parametrii analizati														
	Clor rezidual liber [mg/l]	Turbiditate [NTU]	pH [unitati pH]	Conductivitate [μS/cm]	Duritate [°G]	Subst. organice [mgO ₂ /l]	Cloruri [mg/l]	Nitriti [mg/l]	Amoniu [mg/l]	Bacterii coliforme [nr/100 ml]	E. coli [nr/100 ml]	Enterococi intestinali [nr/100 ml]	UFC 37°C/ml	UFC 22°C/ml	Clostridium Perfringens
CMA (Ordonanta 7/2023)	0.1-0.5	acc. cons	6.5-9.5	2500	min 5	5	250	0.5	0.5	0	0	0	**	**	0
Hateg	0,32	0,55	7,20/ 24,0°C	53,53	1,44	0,62	<2,00	<0.0058	<0.0222	0	0	0	0	0	0
Hunedoara	0,38	0,78	7,19/ 22,53°C	74,53	1,93	0,79	1,80	<0.0065	<0.0286	0	0	0	0	0	0
Calan	0,29	0,43	7,13/ 23,1°C	57,4	1,61	0,76	1,40	<0.0065	<0.0286	0	0	0	0	0	0
Simeria	0,13	0,76	6,80/ 22,8°C	57,6	1,30	0,54	1,96	<0.0065	<0.0286	0	0	0	0	0	0
Geoagiu	0,46	0,17	7,32/ 22,8°C	868	16,06	0,57	20,80	<0.0065	<0.0286	0	0	0	0	0	0
Deva	0,21	0,53	7,17/ 22,6°C	57,3	1,54	0,93	3,70	<0.0062	<0.0142	0	0	0	0	0	0
Brad	0,39	0,50	7,99/ 21,9°C	389	10,95	1,26	8,25	<0.0062	<0.0142	0	0	0	0	0	0

Nota:

- ** Nici o modificare anormala.
- CMA – concentratie maxima admisa conf Ordonanta 7/2023