

Valori medii saptamanale ale parametrilor de potabilitate (18.09 – 24.09.2023)

Punct de recoltare	Parametrii analizati														
	Clor rezidual liber [mg/l]	Turbiditate [NTU]	pH [unitati pH]	Conductivitate [μS/cm]	Duritate [°G]	Subst. organice [mgO ₂ /l]	Cloruri [mg/l]	Nitriti [mg/l]	Amoniu [mg/l]	Bacterii coliforme [nr/100 ml]	E. coli [nr/100 ml]	Enterococi intestinali [nr/100 ml]	UFC 37°C/ml	UFC 22°C/ml	Clostridium Perfringens
CMA (Ordonanta 7/2023)	0.1-0.5	acc. cons	6.5-9.5	2500	min 5	5	250	0.5	0.5	0	0	0	**	**	0
Hateg	0,32	0,36	7,20/ 21,6°C	62,23	1,42	0,71	<2,00	<0.0058	<0.0222	0	0	0	0	0	0
Hunedoara	0,36	0,79	7,24/ 22,50°C	80,31	2,10	0,69	2,24	<0.0065	<0.0286	0	0	0	0	0	0
Calan	0,25	0,43	7,20/ 22,8°C	66,9	1,88	0,82	2,24	<0.0065	<0.0286	0	0	0	0	0	0
Simeria	0,16	0,40	7,23/ 23,0°C	67,2	1,79	1,14	2,81	<0.0065	<0.0286	0	0	0	0	0	0
Geoagiu	0,40	0,22	7,48/ 23,0°C	968	18,86	0,25	21,93	<0.0065	<0.0286	0	0	0	0	0	0
Deva	0.22	0.57	7,16 / 22.0°C	66.2	1.70	0.72	2.3.6	<0.0062	<0.0142	0	0	0	0	0	0
Brad	0.34	0.61	7,87/ 21.8°C	388	10.93	0.95	8.76	<0.0062	<0.0142	0	0	0	0	0	0

Nota:

- ** Nici o modificare anormala.
- CMA – concentratie maxima admisa conf Ordonanta 7/2023