

Valori medii saptamanale ale parametrilor de potabilitate (23.10 – 29.10.2023)

| Punct de recoltare | Parametrii analizati | | | | | | | | | | | | | | |
|-----------------------------------|-------------------------------|----------------------|--------------------|---------------------------|------------------|--|-------------------|-------------------|------------------|-----------------------------------|------------------------|--|-------------|-------------|----------------------------|
| | Clor rezidual liber [mg/l] | Turbiditate [NTU] | pH [unitati pH] | Conductivitate [μS/cm] | Duritate [°G] | Subst. organice [mgO ₂ /l] | Cloruri [mg/l] | Nitriti [mg/l] | Amoniu [mg/l] | Bacterii coliforme [nr/100 ml] | E. coli [nr/100 ml] | Enterococi intestinali [nr/100 ml] | UFC 37°C/ml | UFC 22°C/ml | Clostridium Perfringens |
| CMA (Ordonanta 7/2023) | 0.1-0.5 | acc. cons | 6.5-9.5 | 2500 | min 5 | 5 | 250 | 0.5 | 0.5 | 0 | 0 | 0 | ** | ** | 0 |
| Hateg | 0,39 | 0,39 | 7,02/ 20,7°C | 59,09 | 1,54 | 0,55 | <2,00 | <0.0058 | <0.0222 | 0 | 0 | 0 | 0 | 0 | 0 |
| Hunedoara | 0,39 | 0,76 | 7,35/ 20,33°C | 81,3 | 2,23 | 0,58 | 1,61 | <0.0065 | <0.0286 | 0 | 0 | 0 | 0 | 0 | 0 |
| Calan | 0,36 | 0,86 | 7,56/ 19,5°C | 57,5 | 1,65 | 0,25 | 1,68 | <0.0065 | <0.0286 | 0 | 0 | 0 | 0 | 0 | 0 |
| Simeria | 0,36 | 0,39 | 6,58/ 20,5°C | 60,1 | 1,72 | 0,51 | 1,96 | <0.0065 | <0.0286 | 0 | 0 | 0 | 0 | 0 | 0 |
| Geoagiu | 0,43 | 0,29 | 7,66/ 20,8°C | 838 | 14,51 | 0,44 | 28,39 | <0.0065 | <0.0286 | 0 | 0 | 0 | 0 | 0 | 0 |
| Deva | 0,46 | 0,69 | 7,05 / 20,1°C | 65,4 | 1,63 | 0,67 | 2,91 | <0.0062 | <0.0142 | 0 | 0 | 0 | 0 | 0 | 0 |
| Brad | 0,38 | 0,88 | 8,04/ 19,8°C | 406 | 11,07 | 0,85 | 8,08 | <0.0062 | <0.0142 | 0 | 0 | 0 | 0 | 0 | 0 |

Nota:

- ** Nici o modificare anormala.
- CMA – concentratie maxima admisa conf Ordonanta 7/2023