

**Valori medii saptamanale ale parametrilor de potabilitate (25.09 – 30.09.2023)**

Punct de recoltare	Parametrii analizati														
	Clor rezidual liber [mg/l]	Turbiditate [NTU]	pH [unitati pH]	Conductivitate [μS/cm]	Duritate [°G]	Subst. organice [mgO <sub>2</sub> /l]	Cloruri [mg/l]	Nitriti [mg/l]	Amoniu [mg/l]	Bacterii coliforme [nr/100 ml]	E. coli [nr/100 ml]	Enterococi intestinali [nr/100 ml]	UFC 37°C/ml	UFC 22°C/ml	Clostridium Perfringens
<b>CMA (Ordonanta 7/2023)</b>	<b>0.1-0.5</b>	<b>acc. cons</b>	<b>6.5-9.5</b>	<b>2500</b>	<b>min 5</b>	<b>5</b>	<b>250</b>	<b>0.5</b>	<b>0.5</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>**</b>	<b>**</b>	<b>0</b>
Hateg	0,50	0,52	7,20/ 20,9°C	60,63	1,48	0,63	<2,00	<0.0058	<0.0222	0	0	0	0	0	0
Hunedoara	0,44	1,25	7,16/ 21,50°C	75,15	1,91	0,99	2,76	<0.0065	<0.0286	0	0	0	0	0	0
Calan	0,24	0,50	7,15/ 22,7°C	68,1	1,68	0,51	2,10	<0.0065	<0.0286	0	0	0	0	0	0
Simeria	0,17	1,02	7,10/ 22,0°C	67,6	1,63	0,58	2,10	<0.0065	<0.0286	0	0	0	0	0	0
Geoagiu	0,38	0,19	7,50/ 21,8°C	971	22,23	0,83	28,53	<0.0065	<0.0286	0	0	0	0	0	0
Deva	0.30	0.54	7,07 / 21.6°C	66.6	1.71	0.89	2.19	<0.0062	<0.0142	0	0	0	0	0	0
Brad	0.26	0.67	7,50/ 21.9°C	349	9.36	0.97	6.40	<0.0062	<0.0142	0	0	0	0	0	0

Nota:

- \*\* Nici o modificare anormala.
- CMA – concentratie maxima admisa conf Ordonanta 7/2023