

**Valori medii saptamanale ale parametrilor de potabilitate (4.09 – 10.09.2023)**

Punct de recoltare	Parametrii analizati														
	Clor rezidual liber [mg/l]	Turbiditate [NTU]	pH [unitati pH]	Conductivitate [ $\mu$ S/cm]	Duritate [ $^{\circ}$ G]	Subst. organice [mgO <sub>2</sub> /l]	Cloruri [mg/l]	Nitriti [mg/l]	Amoniu [mg/l]	Bacterii coliforme [nr/100 ml]	E. coli [nr/100 ml]	Enterococi intestinali [nr/100 ml]	UFC 37°C/ml	UFC 22°C/ml	Clostridium Perfringens
<b>CMA (Ordonanta 7/2023)</b>	<b>0.1-0.5</b>	<b>acc. cons</b>	<b>6.5-9.5</b>	<b>2500</b>	<b>min 5</b>	<b>5</b>	<b>250</b>	<b>0.5</b>	<b>0.5</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>**</b>	<b>**</b>	<b>0</b>
Hateg	0,44	0,48	6,90/ 21,5°C	59,10	1,41	0,74	<2,00	<0.0058	<0.0222	0	0	0	0	0	0
Hunedoara	0,41	0,73	7,22/ 22,14°C	92,56	2,28	0,65	1,74	<0.0065	<0.0286	0	0	0	0	0	0
Calan	0,24	0,41	7,30/ 22,9°C	89,3	2,17	0,89	1,82	<0.0065	<0.0286	0	0	0	0	0	0
Simeria	0,16	0,50	7,25/ 23,0°C	96,7	2,15	1,02	1,96	<0.0065	<0.0286	0	0	0	0	0	0
Geoagiu	0,39	0,37	7,24/ 22,4°C	957	21,76	0,83	27,41	<0.0065	<0.0286	0	0	0	0	0	0
Deva	0.25	0.51	7,14/ 22,7°C	63.2	1.65	0.75	2.02	<0.0062	<0.0142	0	0	0	0	0	0
Brad	0.32	0.48	7,78/ 22,9°C	381	10.48	1.35	7.11	<0.0062	<0.0142	0	0	0	0	0	0

Nota:

- \*\* Nici o modificare anormala.
- CMA – concentratie maxima admisa conf Ordonanta 7/2023