

Valori medii saptamanale ale parametrilor de potabilitate (09.10 – 15.10.2023)

Punct de recoltare	Parametrii analizati														
	Clor rezidual liber [mg/l]	Turbiditate [NTU]	pH [unitati pH]	Conductivitate [μS/cm]	Duritate [°G]	Subst. organice [mgO ₂ /l]	Cloruri [mg/l]	Nitriti [mg/l]	Amoniu [mg/l]	Bacterii coliforme [nr/100 ml]	E. coli [nr/100 ml]	Enterococi intestinali [nr/100 ml]	UFC 37°C/ml	UFC 22°C/ml	Clostridium Perfringens
CMA (Ordonanta 7/2023)	0.1-0.5	acc. cons	6.5-9.5	2500	min 5	5	250	0.5	0.5	0	0	0	**	**	0
Hateg	0,40	0,51	7,30/ 20,6°C	62,46	1,53	0,75	<2,00	<0.0058	<0.0222	0	0	0	0	0	0
Hunedoara	0,46	0,77	7,42/ 19,85°C	73,55	2,20	0,53	1,61	<0.0065	<0.0286	0	0	0	0	0	0
Calan	0,42	0,41	7,36/ 21,0°C	60,4	1,95	0,76	1,82	<0.0065	<0.0286	0	0	0	0	0	0
Simeria	0,18	0,53	7,41/ 20,7°C	61,9	1,88	0,32	1,26	<0.0065	<0.0286	0	0	0	0	0	0
Geoagiu	0,48	0,20	7,57/ 19,7°C	872	24,30	0,57	27,13	<0.0065	<0.0286	0	0	0	0	0	0
Deva	0.31	0.44	7,19 / 20,9°C	68.2	1.73	0.79	2.42	<0.0062	<0.0142	0	0	0	0	0	0
Brad	0.36	0.52	7,97/ 20,4°C	402	11.22	0.59	8.08	<0.0062	<0.0142	0	0	0	0	0	0

Nota:

- ** Nici o modificare anormala.
- CMA – concentratie maxima admisa conf Ordonanta 7/2023