

**Valori medii saptamanale ale parametrilor de potabilitate (13.11 – 19.11.2023)**

Punct de recoltare	Parametrii analizati														
	Clor rezidual liber [mg/l]	Turbiditate [NTU]	pH [unitati pH]	Conductivitate [μS/cm]	Duritate [°G]	Subst. organice [mgO <sub>2</sub> /l]	Cloruri [mg/l]	Nitriti [mg/l]	Amoniu [mg/l]	Bacterii coliforme [nr/100 ml]	E. coli [nr/100 ml]	Enterococi intestinali [nr/100 ml]	UFC 37°C/ml	UFC 22°C/ml	Clostridium Perfringens
<b>CMA (Ordonanta 7/2023)</b>	<b>0.1-0.5</b>	<b>acc. cons</b>	<b>6.5-9.5</b>	<b>2500</b>	<b>min 5</b>	<b>5</b>	<b>250</b>	<b>0.5</b>	<b>0.5</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>**</b>	<b>**</b>	<b>0</b>
Hateg	0,40	0,36	7,00/ 20,00°C	60,07	1,57	0,60	<2,00	<0.0058	<0.0222	0	0	0	0	0	0
Hunedoara	0,42	0,96	7,62/ 19,7°C	73,47	2,06	0,96	1,54	<0.0065	<0.0286	0	0	0	0	0	0
Calan	0,38	0,78	7,63/ 18,5°C	62,8	1,81	0,57	1,40	<0.0065	<0.0286	0	0	0	0	0	0
Simeria	0,35	0,52	7,60/ 20,8°C	63,0	1,61	0,70	1,68	<0.0065	<0.0286	0	0	0	0	0	0
Geoagiu	0,47	0,17	7,61/ 19,1°C	884	18,16	0,25	26,14	<0.0065	<0.0286	0	0	0	0	0	0
Deva	0.34	0.41	7.25 / 19.5°C	64.6	1.76	0.86	2.52	<0.0062	<0.0142	0	0	0	0	0	0
Brad	0.29	0.66	7.56/ 19.2°C	334	9.60	0.83	5.39	<0.0062	<0.0142	0	0	0	0	0	0

Nota:

- \*\* Nici o modificare anormala.
- CMA – concentratie maxima admisa conf Ordonanta 7/2023