

Valori medii saptamanale ale parametrilor de potabilitate (20.11 – 26.11.2023)

Punct de recoltare	Parametrii analizati														
	Clor rezidual liber [mg/l]	Turbiditate [NTU]	pH [unitati pH]	Conductivitate [μS/cm]	Duritate [°G]	Subst. organice [mgO ₂ /l]	Cloruri [mg/l]	Nitriti [mg/l]	Amoniu [mg/l]	Bacterii coliforme [nr/100 ml]	E. coli [nr/100 ml]	Enterococi intestinali [nr/100 ml]	UFC 37°C/ml	UFC 22°C/ml	Clostridium Perfringens
CMA (Ordonanta 7/2023)	0.1-0.5	acc. cons	6.5-9.5	2500	min 5	5	250	0.5	0.5	0	0	0	**	**	0
Hateg	0,31	0,40	7,11/ 21,09°C	60,77	1,46	0,59	<2,00	<0.0058	<0.0222	0	0	0	0	0	0
Hunedoara	0,40	1,07	7,33/ 19,06°C	70,97	2,07	0,53	1,75	<0.0065	<0.0286	0	0	0	0	0	0
Calan	0,40	0,36	7,53/ 19,4°C	59,6	1,79	0,44	1,82	<0.0065	<0.0286	0	0	0	0	0	0
Simeria	0,26	1,69	7,69/ 19,3°C	70,1	2,24	0,70	2,10	<0.0065	<0.0286	0	0	0	0	0	0
Geoagiu	0,38	0,42	7,88/ 19,5°C	856	24,57	0,57	26,99	<0.0065	<0.0286	0	0	0	0	0	0
Deva	0.26	0.47	7.21 / 19.1°C	65.8	1.79	0.81	2.13	<0.0062	<0.0142	0	0	0	0	0	0
Brad	0.38	0.55	7.66/ 19.3°C	342	9.90	0.98	6.40	<0.0062	<0.0142	0	0	0	0	0	0

Nota:

- ** Nici o modificare anormala.
- CMA – concentratie maxima admisa conf Ordonanta 7/2023