

Valori medii saptamanale ale parametrilor de potabilitate (30.10 – 05.11.2023)

Punct de recoltare	Parametrii analizati														
	Clor rezidual liber [mg/l]	Turbiditate [NTU]	pH [unitati pH]	Conductivitate [μS/cm]	Duritate [°G]	Subst. organice [mgO ₂ /l]	Cloruri [mg/l]	Nitriti [mg/l]	Amoniu [mg/l]	Bacterii coliforme [nr/100 ml]	E. coli [nr/100 ml]	Enterococi intestinali [nr/100 ml]	UFC 37°C/ml	UFC 22°C/ml	Clostridium Perfringens
CMA (Ordonanta 7/2023)	0.1-0.5	acc. cons	6.5-9.5	2500	min 5	5	250	0.5	0.5	0	0	0	**	**	0
Hateg	0,39	0,47	7,10/ 19,07°C	58,17	1,59	0,70	<2,00	<0.0058	<0.0222	0	0	0	0	0	0
Hunedoara	0,39	0,76	7,35/ 20,33°C	81,3	2,23	0,58	1,61	<0.0065	<0.0286	0	0	0	0	0	0
Calan	0,37	0,93	7,58/ 20,4°C	57,2	1,50	0,32	1,40	<0.0065	<0.0286	0	0	0	0	0	0
Simeria	0,43	0,48	7,73/ 19,7°C	82,9	2,23	0,51	1,96	<0.0065	<0.0286	0	0	0	0	0	0
Geoagiu	0,45	0,40	7,77/ 19,6°C	879	25,30	0,64	26,00	<0.0065	<0.0286	0	0	0	0	0	0
Deva	0.48	0.39	7,19 / 19,5°C	63.2	1.75	0.81	2.36	<0.0062	<0.0142	0	0	0	0	0	0
Brad	0.32	1.15	7,71/ 19,3°C	392	11.31	1.06	6.74	<0.0062	<0.0142	0	0	0	0	0	0

Nota:

- ** Nici o modificare anormala.
- CMA – concentratie maxima admisa conf Ordonanta 7/2023