

**Valori medii saptamanale ale parametrilor de potabilitate (04.12 – 10.12.2023)**

Punct de recoltare	Parametrii analizati														
	Clor rezidual liber [mg/l]	Turbiditate [NTU]	pH [unitati pH]	Conductivitate [μS/cm]	Duritate [°G]	Subst. organice [mgO <sub>2</sub> /l]	Cloruri [mg/l]	Nitriti [mg/l]	Amoniu [mg/l]	Bacterii coliforme [nr/100 ml]	E. coli [nr/100 ml]	Enterococi intestinali [nr/100 ml]	UFC 37°C/ml	UFC 22°C/ml	Clostridium Perfringens
<b>CMA (Ordonanta 7/2023)</b>	<b>0.1-0.5</b>	<b>acc. cons</b>	<b>6.5-9.5</b>	<b>2500</b>	<b>min 5</b>	<b>5</b>	<b>250</b>	<b>0.5</b>	<b>0.5</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>**</b>	<b>**</b>	<b>0</b>
Hateg	0,32	0,62	7,20/ 20,60°C	65,51	1,47	0,71	<2,00	<0.0058	<0.0222	0	0	0	0	0	0
Hunedoara	0,39	1,07	7,70/ 19,06°C	67,07	1,88	1,07	1,75	<0.0065	<0.0286	0	0	0	0	0	0
Calan	0,36	0,53	7,89/ 19,5°C	74,7	2,10	0,57	1,96	<0.0065	<0.0286	0	0	0	0	0	0
Simeria	0,38	0,68	7,83/ 19,8°C	77,3	2,24	0,76	2,53	<0.0065	<0.0286	0	0	0	0	0	0
Geoagiu	0,42	0,34	8,09/ 20,0°C	835	24,03	0,64	24,74	<0.0065	<0.0286	0	0	0	0	0	0
Deva	0.38	0.47	7.16 / 19.9°C	68.7	1.80	0.72	2.54	<0.0062	<0.0142	0	0	0	0	0	0
Brad	0.41	0.52	7.53/ 19.2°C	368	9.76	0.73	7.41	<0.0062	<0.0142	0	0	0	0	0	0

Nota:

- \*\* Nici o modificare anormala.
- CMA – concentratie maxima admisa conf Ordonanta 7/2023