

**Valori medii saptamanale ale parametrilor de potabilitate (11.12 – 17.12.2023)**

Punct de recoltare	Parametrii analizati														
	Clor rezidual liber [mg/l]	Turbiditate [NTU]	pH [unitati pH]	Conductivitate [μS/cm]	Duritate [°G]	Subst. organice [mgO <sub>2</sub> /l]	Cloruri [mg/l]	Nitriti [mg/l]	Amoniu [mg/l]	Bacterii coliforme [nr/100 ml]	E. coli [nr/100 ml]	Enterococi intestinali [nr/100 ml]	UFC 37°C/ml	UFC 22°C/ml	Clostridium Perfringens
<b>CMA (Ordonanta 7/2023)</b>	<b>0.1-0.5</b>	<b>acc. cons</b>	<b>6.5-9.5</b>	<b>2500</b>	<b>min 5</b>	<b>5</b>	<b>250</b>	<b>0.5</b>	<b>0.5</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>**</b>	<b>**</b>	<b>0</b>
Hateg	0,36	0,66	7,30/ 19,9°C	65,03	1,59	0,75	<2,00	<0.0058	<0.0222	0	0	0	0	0	0
Hunedoara	0,36	0,62	7,80/ 19,12°C	67,56	2,02	0,67	1,69	<0.0065	<0.0286	0	0	0	0	0	0
Calan	0,40	0,66	7,73/ 19,2°C	76,3	2,10	0,84	2,38	<0.0065	<0.0286	0	0	0	0	0	0
Simeria	0,43	0,78	7,67/ 19,5°C	80,7	2,24	1,02	3,93	<0.0065	<0.0286	0	0	0	0	0	0
Geoagiu	0,39	0,24	7,88/ 19,0°C	820	22,44	0,19	22,07	<0.0065	<0.0286	0	0	0	0	0	0
Deva	0.33	0.56	7.19 / 19.4°C	71.2	1.76	0.74	2.12	<0.0062	<0.0142	0	0	0	0	0	0
Brad	0.38	0.40	7.14/ 19.1°C	387	10.16	0.75	11.45	<0.0062	<0.0142	0	0	0	0	0	0

Nota:

- \*\* Nici o modificare anormala.
- CMA – concentratie maxima admisa conf Ordonanta 7/2023