

Valori medii saptamanale ale parametrilor de potabilitate (18.12 – 24.12.2023)

Punct de recoltare	Parametrii analizati														
	Clor rezidual liber [mg/l]	Turbiditate [NTU]	pH [unitati pH]	Conductivitate [μS/cm]	Duritate [°G]	Subst. organice [mgO ₂ /l]	Cloruri [mg/l]	Nitriti [mg/l]	Amoniu [mg/l]	Bacterii coliforme [nr/100 ml]	E. coli [nr/100 ml]	Enterococi intestinali [nr/100 ml]	UFC 37°C/ml	UFC 22°C/ml	Clostridium Perfringens
CMA (Ordonanta 7/2023)	0.1-0.5	acc. cons	6.5-9.5	2500	min 5	5	250	0.5	0.5	0	0	0	**	**	0
Hateg	0,32	0,57	7,10/ 20,8°C	65,88	1,62	0,71	<2,00	<0.0058	<0.0222	0	0	0	0	0	0
Hunedoara	0,42	0,65	7,75/ 18,73°C	73,12	2,04	0,57	1,82	<0.0065	<0.0286	0	0	0	0	0	0
Calan	0,30	0,58	7,88/ 18,1°C	64,4	2,04	0,44	1,82	<0.0065	<0.0286	0	0	0	0	0	0
Simeria	0,39	0,83	7,59/ 20,0°C	66,8	1,95	1,08	1,68	<0.0065	<0.0286	0	0	0	0	0	0
Geoagiu	0,42	0,39	7,69/ 19,4°C	839	23,82	0,38	22,74	<0.0065	<0.0286	0	0	0	0	0	0
Deva	0.35	0.53	7,11/ 19,8°C	70.11	1.74	0.81	2.69	<0.0062	<0.0142	0	0	0	0	0	0
Brad	0.36	0.44	7,18/ 19,7°C	365	9.70	0.90	8.22	<0.0062	<0.0142	0	0	0	0	0	0

Nota:

- ** Nici o modificare anormala.
- CMA – concentratie maxima admisa conf Ordonanta 7/2023