

**Valori medii saptamanale ale parametrilor de potabilitate (27.11 – 03.12.2023)**

Punct de recoltare	Parametrii analizati														
	Clor rezidual liber [mg/l]	Turbiditate [NTU]	pH [unitati pH]	Conductivitate [μS/cm]	Duritate [°G]	Subst. organice [mgO <sub>2</sub> /l]	Cloruri [mg/l]	Nitriti [mg/l]	Amoniu [mg/l]	Bacterii coliforme [nr/100 ml]	E. coli [nr/100 ml]	Enterococi intestinali [nr/100 ml]	UFC 37°C/ml	UFC 22°C/ml	Clostridium Perfringens
<b>CMA (Ordonanta 7/2023)</b>	<b>0.1-0.5</b>	<b>acc. cons</b>	<b>6.5-9.5</b>	<b>2500</b>	<b>min 5</b>	<b>5</b>	<b>250</b>	<b>0.5</b>	<b>0.5</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>**</b>	<b>**</b>	<b>0</b>
Hateg	0,32	0,42	7,20/ 20,00°C	61,33	1,58	0,59	<2,00	<0.0058	<0.0222	0	0	0	0	0	0
Hunedoara	0,42	0,86	7,58/ 18,96°C	72,46	2,13	0,57	1,68	<0.0065	<0.0286	0	0	0	0	0	0
Calan	0,49	0,66	7,53/ 19,4°C	66,6	1,79	0,84	2,09	<0.0065	<0.0286	0	0	0	0	0	0
Simeria	0,47	0,76	7,69/ 19,3°C	69,2	2,12	0,93	2,16	<0.0065	<0.0286	0	0	0	0	0	0
Geoagiu	0,48	0,29	7,88/ 19,5°C	762	19,57	0,42	20,34	<0.0065	<0.0286	0	0	0	0	0	0
Deva	0.37	0.54	7.29 / 19.4°C	66.5	1.78	0.69	2.04	<0.0062	<0.0142	0	0	0	0	0	0
Brad	0.49	0.22	7.19/ 19.0°C	385	10.28	0.62	7.60	<0.0062	<0.0142	0	0	0	0	0	0

Nota:

- \*\* Nici o modificare anormala.
- CMA – concentratie maxima admisa conf Ordonanta 7/2023