

Valori medii saptamanale ale parametrilor de potabilitate (01.01 – 07.01.2024)

Punct de recoltare	Parametrii analizati														
	Clor rezidual liber [mg/l]	Turbiditate [NTU]	pH [unitati pH]	Conductivitate [μS/cm]	Duritate [°G]	Subst. organice [mgO ₂ /l]	Cloruri [mg/l]	Nitriti [mg/l]	Amoniu [mg/l]	Bacterii coliforme [nr/100 ml]	E. coli [nr/100 ml]	Enterococi intestinali [nr/100 ml]	UFC 37°C/ml	UFC 22°C/ml	Clostridium Perfringens
CMA (Ordonanta 7/2023)	0.1-0.5	acc. cons	6.5-9.5	2500	min 5	5	250	0.5	0.5	0	0	0	**	**	0
Hateg	0,39	0,64	7,20/ 21,6°C	66,67	1,46	0,70	<2,00	<0.0058	<0.0222	0	0	0	0	0	0
Hunedoara	0,40	0,65	7,93/ 19,52°C	77,98	2,25	0,57	1,54	<0.0065	<0.0286	0	0	0	0	0	0
Calan	0,41	0,47	7,86/ 20,6°C	67,6	1,76	0,70	2,10	<0.0065	<0.0286	0	0	0	0	0	0
Simeria	0,35	0,52	7,80/ 20,1°C	65,9	1,74	0,96	1,96	<0.0065	<0.0286	0	0	0	0	0	0
Geoagiu	0,46	0,23	7,88/ 19,2°C	839	23,38	0,19	23,09	<0.0065	<0.0286	0	0	0	0	0	0
Deva	0.32	0.51	7,16/ 19,4°C	71.2	1.76	0.72	1.68	<0.0062	<0.0142	0	0	0	0	0	0
Brad	0.39	0.42	7,70/ 19,6°C	375	8.72	0.66	6.74	<0.0062	<0.0142	0	0	0	0	0	0

Nota:

- ** Nici o modificare anormala.
- CMA – concentratie maxima admisa conf Ordonanta 7/2023