

**Valori medii saptamanale ale parametrilor de potabilitate (22.01 – 28.01.2024)**

Punct de recoltare	Parametrii analizati														
	Clor rezidual liber [mg/l]	Turbiditate [NTU]	pH [unitati pH]	Conductivitate [μS/cm]	Duritate [°G]	Subst. organice [mgO <sub>2</sub> /l]	Cloruri [mg/l]	Nitriti [mg/l]	Amoniu [mg/l]	Bacterii coliforme [nr/100 ml]	E. coli [nr/100 ml]	Enterococi intestinali [nr/100 ml]	UFC 37°C/ml	UFC 22°C/ml	Clostridium Perfringens
<b>CMA (Ordonanta 7/2023)</b>	<b>0.1-0.5</b>	<b>4</b>	<b>6.5-9.5</b>	<b>2500</b>	<b>min 5</b>	<b>5</b>	<b>250</b>	<b>0.5</b>	<b>0.5</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>**</b>	<b>**</b>	<b>0</b>
Hateg	0,43	0,58	7,34/ 22,1°C	67,05	1,64	0,68	<2,00	<0.0058	<0.0222	0	0	0	0	0	0
Hunedoara	0,39	0,64	7,28/ 19,09°C	78,02	2,20	0,53	1,34	<0.0065	<0.0286	0	0	0	0	0	0
Calan	0,42	0,47	7,54/ 19,4°C	65,9	1,81	0,70	1,40	<0.0065	<0.0286	0	0	0	0	0	0
Simeria	0,38	0,53	7,61/ 19,3°C	64,7	1,92	0,64	1,54	<0.0065	<0.0286	0	0	0	0	0	0
Geoagiu	0,37	0,25	7,53/ 18,6°C	823	19,64	0,32	25,48	<0.0065	<0.0286	0	0	0	0	0	0
Deva	0,33	0,46	7,18/ 19,4°C	71,8	1,79	0,85	2,02	<0.0062	<0.0142	0	0	0	0	0	0
Brad	0,34	0,42	7,28/ 19,9°C	360	9,93	0,64	9,77	<0.0062	<0.0142	0	0	0	0	0	0

Nota:

- \*\* Nici o modificare anormala.
- CMA – concentratie maxima admisa conf Ordonanta 7/2023