

**Valori medii saptamanale ale parametrilor de potabilitate (27.12 – 31.12.2023)**

Punct de recoltare	Parametrii analizati														
	Clor rezidual liber [mg/l]	Turbiditate [NTU]	pH [unitati pH]	Conductivitate [ $\mu$ S/cm]	Duritate [ $^{\circ}$ G]	Subst. organice [mgO <sub>2</sub> /l]	Cloruri [mg/l]	Nitriti [mg/l]	Amoniu [mg/l]	Bacterii coliforme [nr/100 ml]	E. coli [nr/100 ml]	Enterococi intestinali [nr/100 ml]	UFC 37°C/ml	UFC 22°C/ml	Clostridium Perfringens
<b>CMA (Ordonanta 7/2023)</b>	<b>0.1-0.5</b>	<b>acc. cons</b>	<b>6.5-9.5</b>	<b>2500</b>	<b>min 5</b>	<b>5</b>	<b>250</b>	<b>0.5</b>	<b>0.5</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>**</b>	<b>**</b>	<b>0</b>
Hateg	0,33	0,52	7,20/ 20,1°C	65,80	1,62	0,58	<2,00	<0.0058	<0.0222	0	0	0	0	0	0
Hunedoara	0,39	0,73	7,78/ 18,8°C	72,94	2,01	0,76	1,68	<0.0065	<0.0286	0	0	0	0	0	0
Calan	0,36	0,70	7,80/ 19,3°C	68,1	1,72	0,76	1,68	<0.0065	<0.0286	0	0	0	0	0	0
Simeria	0,42	0,94	7,89/ 19,2°C	66,3	1,79	0,64	1,82	<0.0065	<0.0286	0	0	0	0	0	0
Geoagiu	0,43	0,29	7,24/ 19,3°C	908	22,28	0,64	22,49	<0.0065	<0.0286	0	0	0	0	0	0
Deva	0,29	0,60	7,13/ 19,5°C	71,6	1,80	0,68	2,02	<0.0062	<0.0142	0	0	0	0	0	0
Brad	0,37	0,36	7,19/ 19,5°C	343	9,24	0,65	10,44	<0.0062	<0.0142	0	0	0	0	0	0

Nota:

- \*\* Nici o modificare anormala.
- CMA – concentratie maxima admisa conf Ordonanta 7/2023