

Valori medii saptamanale ale parametrilor de potabilitate (29.01.2024– 04.02.2024)

Punct de recoltare	Parametrii analizati														
	Clor rezidual liber [mg/l]	Turbiditate [NTU]	pH [unitati pH]	Conductivitate [μ S/cm]	Duritate [$^{\circ}$ G]	Subst. organice [mgO ₂ /l]	Cloruri [mg/l]	Nitriti [mg/l]	Amoniu [mg/l]	Bacterii coliforme [nr/100 ml]	E. coli [nr/100 ml]	Enterococi intestinali [nr/100 ml]	UFC 37°C/ml	UFC 22°C/ml	Clostridium Perfringens
CMA (Ordonanta 7/2023)	0.1-0.5	4.0	6.5-9.5	2500	min 5	5	250	0.5	0.5	0	0	0	**	**	0
Hateg	0.39	0.58	7.4	66.65	1.59	0.63	<2.00	<0.0058	<0.0222	0	0	0	0	0	0
Hunedoara	0,46	0,46	7,31	81,03	2,25	0,44	1,42	<0.0065	<0.0286	0	0	0	0	0	0
Calan	0,36	0,72	7,73	79,8	2,19	0,38	1,54	<0.0065	<0.0286	0	0	0	0	0	0
Simeria	0,23	0,83	7,80	82,3	2,23	0,44	1,40	<0.0065	<0.0286	0	0	0	0	0	0
Geoagiu	0,41	0,16	7,67	789	21,94	0,32	23,05	<0.0065	<0.0286	0	0	0	0	0	0
Deva	0.34	0.43	7.20	72.5	1.7	0.75	2.36	<0.0062	<0.0142	0	0	0	0	0	0
Brad	0.39	0.53	7.23	382	9.93	0.90	11.79	<0.0062	<0.0142	0	0	0	0	0	0

Nota:

- ** Nici o modificare anormala.
- CMA – concentratie maxima admisa conf Ordonanta 7/2023