

Valori medii saptamanale ale parametrilor de potabilitate (5.02 –11.02.2024)

Punct de recoltare	Parametrii analizati														
	Clor rezidual liber [mg/l]	Turbiditate [NTU]	pH [unitati pH]	Conductivitate [μS/cm]	Duritate [°G]	Subst. organice [mgO ₂ /l]	Cloruri [mg/l]	Nitriti [mg/l]	Amoniu [mg/l]	Bacterii coliforme [nr/100 ml]	E. coli [nr/100 ml]	Enterococi intestinali [nr/100 ml]	UFC 37°C/ml	UFC 22°C/ml	Clostridium Perfringens
CMA (Ordonanta 7/2023)	0.1-0.5	4	6.5-9.5	2500	min 5	5	250	0.5	0.5	0	0	0	**	**	0
Hateg	0,45	0,55	6,90	65,82	1,56	0,67	<2,00	<0.0058	<0.0222	0	0	0	0	0	0
Hunedoara	0,41	0,93	7,34	78,25	2,24	0,75	1,68	<0.0065	<0.0286	0	0	0	0	0	0
Calan	0,44	0,65	7,52	65,9	1,92	0,51	1,410	<0.0065	<0.0286	0	0	0	0	0	0
Simeria	0,45	0,53	7,26	77,8	2,55	0,70	1,68	<0.0065	<0.0286	0	0	0	0	0	0
Geoagiu	0,42	0,17	7,65	805	19,43	0,32	22,77	<0.0065	<0.0286	0	0	0	0	0	0
Deva	0,35	0,65	7,15	72.5	1.85	0.70	2.02	<0.0062	<0.0142	0	0	0	0	0	0
Brad	0,41	0,72	7,21	378	9,80	0,70	12,80	<0.0062	<0.0142	0	0	0	0	0	0

Nota:

- ** Nici o modificare anormala.
- CMA – concentratie maxima admisa conf Ordonanta 7/202