

Valori medii săptămânale ale parametrilor de potabilitate (04.03.2024– 10.03.2024)

Punct de recoltare	Parametrii analizati														
	Clor rezidual liber [mg/l]	Turbiditate [NTU]	pH [unitati pH]	Conductivitate [μS/cm]	Duritate [°G]	Subst. organice [mgO ₂ /l]	Cloruri [mg/l]	Nitriti [mg/l]	Amoniu [mg/l]	Bacterii coliforme [nr/100 ml]	E. coli [nr/100 ml]	Enterococi intestinali [nr/100 ml]	UFC 37°C/ml	UFC 22°C/ml	Clostridium Perfringens
CMA (Ordonanta 7/2023)	0.1-0.5	4.0	6.5-9.5	2500	min 5	5	250	0.5	0.5	0	0	0	**	**	0
Hateg	0.32	0.44	7.10	70.17	1.76	0.65	<2.00	<0.0058	<0.0222	0	0	0	0	0	0
Hunedoara	0,39	0,74	7,35	81,32	2,33	0,89	1,73	<0.0065	<0.0286	0	0	0	0	0	0
Calan	0,31	0,41	7,36	71,9	1,99	0,57	1,82	<0.0065	<0.0286	0	0	0	0	0	0
Simeria	0,36	0,61	7,44	75,3	2,35	0,44	1,68	<0.0065	<0.0286	0	0	0	0	0	0
Geoagiu	0,35	0,33	7,54	792	18,83	0,64	23,19	<0.0065	<0.0286	0	0	0	0	0	0
Deva	0.30	0.47	7.19	78.4	1.90	0.72	2.02	<0.0062	<0.0142	0	0	0	0	0	0
Brad	0.34	0.40	7.96	345	9.34	0.51	6.74	<0.0062	<0.0142	0	0	0	0	0	0

Nota:

- ** Nici o modificare anormala.
- CMA – concentratie maxima admisa conf Ordonanta 7/2023