

Valori medii saptamanale ale parametrilor de potabilitate 11.03 –17.03.2024)

| Punct de recoltare | Parametrii analizati | | | | | | | | | | | | | | |
|-----------------------------------|-------------------------------|----------------------|--------------------|---------------------------|------------------|--|-------------------|-------------------|------------------|-----------------------------------|------------------------|--|-------------|-------------|----------------------------|
| | Clor rezidual liber [mg/l] | Turbiditate [NTU] | pH [unitati pH] | Conductivitate [μS/cm] | Duritate [°G] | Subst. organice [mgO ₂ /l] | Cloruri [mg/l] | Nitriti [mg/l] | Amoniu [mg/l] | Bacterii coliforme [nr/100 ml] | E. coli [nr/100 ml] | Enterococi intestinali [nr/100 ml] | UFC 37°C/ml | UFC 22°C/ml | Clostridium Perfringens |
| CMA (Ordonanta 7/2023) | 0.1-0.5 | acc. cons | 6.5-9.5 | 2500 | min 5 | 5 | 250 | 0.5 | 0.5 | 0 | 0 | 0 | ** | ** | 0 |
| Hateg | 0.42 | 0.46 | 7.10 | 71.15 | 1.75 | 0.66 | <2,00 | <0.0058 | <0.0222 | 0 | 0 | 0 | 0 | 0 | 0 |
| Hunedoara | 0,44 | 0,68 | 7,58 | 88,37 | 2,27 | 0,78 | 1,72 | <0.0065 | <0.0286 | 0 | 0 | 0 | 0 | 0 | 0 |
| Calan | 0,45 | 0,44 | 7,47 | 72,0 | 2,24 | 0,76 | 1,82 | <0.0065 | <0.0286 | 0 | 0 | 0 | 0 | 0 | 0 |
| Simeria | 0,40 | 1,14 | 7,46 | 76,4 | 2,24 | 0,64 | 1,40 | <0.0065 | <0.0286 | 0 | 0 | 0 | 0 | 0 | 0 |
| Geoagiu | 0,45 | 0,14 | 7,46 | 787 | 21,96 | 0,32 | 22,91 | <0.0065 | <0.0286 | 0 | 0 | 0 | 0 | 0 | 0 |
| Deva | 0.37 | 0.66 | 7,22 | 77.4 | 1.90 | 0.58 | 2.02 | <0.0062 | <0.0142 | 0 | 0 | 0 | 0 | 0 | 0 |
| Brad | 0.36 | 0.41 | 7,34 | 321 | 9.11 | 0.77 | 8.08 | <0.0062 | <0.0142 | 0 | 0 | 0 | 0 | 0 | 0 |

Nota:

- ** Nici o modificare anormala.
- CMA – concentratie maxima admisa conf Ordonanta 7/2023