

Valori medii saptamanale ale parametrilor de potabilitate (01.04 –07.04.2024)

Punct de recoltare	Parametrii analizati														
	Clor rezidual liber [mg/l]	Turbiditate [NTU]	pH [unitati pH]	Conductivitate [μS/cm]	Duritate [°G]	Subst. organice [mgO ₂ /l]	Cloruri [mg/l]	Nitriti [mg/l]	Amoniu [mg/l]	Bacterii coliforme [nr/100 ml]	E. coli [nr/100 ml]	Enterococi intestinali [nr/100 ml]	UFC 37°C/ml	UFC 22°C/ml	Clostridium Perfringens
CMA	0.1-0.5	4	6.5-9.5	2500	min 5	5	250	0.5	0.5	0	0	0	**	**	0
Hateg	0,41	0,47	7,10	71,2	1,82	0,72	<2,00	<0,0058	<0,0222	0	0	0	0	0	0
Hunedoara	0,30	0,85	7,28	66,30	1,82	0,87	2,22	<0.0065	<0.0286	0	0	0	0	0	0
Calan	0,21	0,55	7,53	76,7	1,92	0,69	1,40	<0.0065	<0.0286	0	0	0	0	0	0
Simeria	0,42	0,42	7,61	78,2	2,26	0,51	1,26	<0.0065	<0.0286	0	0	0	0	0	0
Geoagiu	0,39	0,27	7,41	782	22,44	0,57	22,91	<0.0065	<0.0286	0	0	0	0	0	0
Deva	0,34	0,65	7,22	79,1	1,95	0,71	2,02	<0.0062	<0.0142	0	0	0	0	0	0
Brad	0,36	0,47	7,46	308	8,70	0,70	7,07	<0.0062	<0.0142	0	0	0	0	0	0

Nota:

- ** Nici o modificare anormala.
- CMA – concentratie maxima admisa conf Ordonanta 7/2023, HG 971/2023