

Valori medii saptamanale ale parametrilor de potabilitate (08.04 –14.04.2024)

Punct de recoltare	Parametrii analizati														
	Clor rezidual liber [mg/l]	Turbiditate [NTU]	pH [unitati pH]	Conductivitate [μS/cm]	Duritate [°G]	Subst. organice [mgO ₂ /l]	Cloruri [mg/l]	Nitriti [mg/l]	Amoniu [mg/l]	Bacterii coliforme [nr/100 ml]	E. coli [nr/100 ml]	Enterococi intestinali [nr/100 ml]	UFC 37°C/ml	UFC 22°C/ml	Clostridium Perfringens
CMA	0.1-0.5	4	6.5-9.5	2500	min 5	5	250	0.5	0.5	0	0	0	**	**	0
Hateg	0,38	0,45	7,2/20,9	73,85	1,76	0,72	<2,00	<0,0058	<0,0222	0	0	0	0	0	0
Hunedoara	0,38	0,71	7,11	55,50	1,51	1,01	1,52	<0.0065	<0.0286	0	0	0	0	0	0
Calan	0,23	0,41	7,50	72,6	2,22	0,44	1,68	<0.0065	<0.0286	0	0	0	0	0	0
Simeria	0,44	0,51	7,38	75,4	2,35	0,25	1,68	<0.0065	<0.0286	0	0	0	0	0	0
Geoagiu	0,38	0,30	7,32	810	22,48	0,64	23,19	<0.0065	<0.0286	0	0	0	0	0	0
Deva	0,42	0,56	7,37	80,1	2,00	0,64	2,02	<0.0062	<0.0142	0	0	0	0	0	0
Brad	0,30	0,32	7,23	324	8,81	0,73	6.40	<0.0062	<0.0142	0	0	0	0	0	0

Nota:

- ** Nici o modificare anormala.
- CMA – concentratie maxima admisa conf Ordonanta 7/2023, HG 971/2023