

**Valori medii saptamanale ale parametrilor de potabilitate (10.06 –16.06.2024)**

Punct de recoltare	Parametrii analizati														
	Clor rezidual liber [mg/l]	Turbiditate [NTU]	pH [unitati pH]	Conductivitate [μS/cm]	Duritate [°G]	Subst. organice [mgO <sub>2</sub> /l]	Cloruri [mg/l]	Nitriti [mg/l]	Amoniu [mg/l]	Bacterii coliforme [nr/100 ml]	E. coli [nr/100 ml]	Enterococi intestinali [nr/100 ml]	UFC 37°C/ml	UFC 22°C/ml	Clostridium Perfringens
<b>CMA</b>	<b>0.1-0.5</b>	<b>4</b>	<b>6.5-9.5</b>	<b>2500</b>	<b>min 5</b>	<b>5</b>	<b>250</b>	<b>0.5</b>	<b>0.5</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>**</b>	<b>**</b>	<b>0</b>
Hateg	0,36	0,56	7,2	62,19	1,56	0,64	<2,00	<0,0058	<0,0222	0	0	0	0	0	0
Hunedoara	0,41	0,40	7,43	65,22	1,83	1,02	1,48	<0.0065	<0.0286	0	0	0	0	0	0
Calan	0,29	0,61	7,29	69,8	2,00	1,08	1,86	<0.0065	<0.0286	0	0	0	0	0	0
Simeria	0,33	0,57	7,12	72,4	2,25	1,21	1,72	<0.0065	<0.0286	0	0	0	0	0	0
Geoagiu	0,32	0,19	7,43	840	23,22	0,32	25,38	<0.0065	<0.0286	0	0	0	0	0	0
Deva	0,29	0,53	6,95	67,4	1,70	0,60	2,02	<0,0062	<0,0142	0	0	0	0	0	0
Brad	0,35	0,55	7,26	378	10,16	0,93	6,40	<0,0062	<0,0142	0	0	0	0	0	0

Nota:

- \*\* Nici o modificare anormala.
- CMA – concentratie maxima admisa conf Ordonanta 7/2023, HG 971/2023