

Valori medii saptamanale ale parametrilor de potabilitate (22.07 –28.07.2024)

| Punct de recoltare | Parametrii analizati | | | | | | | | | | | | | | |
|--------------------|-------------------------------|----------------------|--------------------|---------------------------|------------------|--|-------------------|-------------------|------------------|-----------------------------------|------------------------|--|-------------|-------------|----------------------------|
| | Clor rezidual liber [mg/l] | Turbiditate [NTU] | pH [unitati pH] | Conductivitate [μS/cm] | Duritate [°G] | Subst. organice [mgO ₂ /l] | Cloruri [mg/l] | Nitriti [mg/l] | Amoniu [mg/l] | Bacterii coliforme [nr/100 ml] | E. coli [nr/100 ml] | Enterococi intestinali [nr/100 ml] | UFC 37°C/ml | UFC 22°C/ml | Clostridium Perfringens |
| CMA | 0.1-0.5 | 4 | 6.5-9.5 | 2500 | min 5 | 5 | 250 | 0.5 | 0.5 | 0 | 0 | 0 | ** | ** | 0 |
| Hateg | 0,23 | 0,47 | 7,3 | 69,42 | 1,54 | 0,66 | <2,00 | <0,0058 | <0,0222 | 0 | 0 | 0 | 0 | 0 | 0 |
| Hunedoara | 0,41 | 0,91 | 7,35 | 78,77 | 2,30 | 1,17 | 3,13 | <0,0065 | <0,0286 | 0 | 0 | 0 | 0 | 0 | 0 |
| Calan | 0,18 | 0,97 | 7,52 | 72,9 | 2,04 | 0,95 | 2,86 | <0,0065 | <0,0286 | 0 | 0 | 0 | 0 | 0 | 0 |
| Simeria | 0,17 | 0,39 | 7,60 | 75,5 | 2,11 | 1,02 | 2,86 | <0,0065 | <0,0286 | 0 | 0 | 0 | 0 | 0 | 0 |
| Geoagiu | 0,38 | 0,26 | 7,31 | 871 | 22,01 | 1,15 | 28,97 | <0,0065 | <0,0286 | 0 | 0 | 0 | 0 | 0 | 0 |
| Deva | 0,29 | 0,42 | 7,16 | 73,1 | 1,71 | 0,79 | 3,17 | <0,0062 | <0,0142 | 0 | 0 | 0 | 0 | 0 | 0 |
| Brad | 0,34 | 0,61 | 7,59 | 393 | 9,96 | 0,72 | 8,33 | <0,0062 | <0,0142 | 0 | 0 | 0 | 0 | 0 | 0 |

Nota:

- ** Nici o modificare anormala.
- CMA – concentratie maxima admisa conf Ordonanta 7/2023, HG 971/2023