

Valori medii saptamanale ale parametrilor de potabilitate (05.08.2024– 11.08.2024)

Punct de recoltare	Parametrii analizati														
	Clor rezidual liber [mg/l]	Turbiditate [NTU]	pH [unitati pH]	Conductivitate [μS/cm]	Duritate [°G]	Subst. organice [mgO ₂ /l]	Cloruri [mg/l]	Nitriti [mg/l]	Amoniu [mg/l]	Bacterii coliforme [nr/100 ml]	E. coli [nr/100 ml]	Enterococi intestinali [nr/100 ml]	UFC 37°C/ml	UFC 22°C/ml	Clostridium Perfringens
CMA	0.1-0.5	4	6.5-9.5	2500	min 5	5	250	0.5	0.5	0	0	0	**	**	0
Hateg	0,29	0,38	7,5	70,83	1,56	0,65	<2,00	<0,0058	<0,0222	0	0	0	0	0	0
Hunedoara	0,38	0,68	7,49	84,36	2,29	0,68	1,54	<0.0065	<0.0286	0	0	0	0	0	0
Calan	0,22	0,73	7,42	68,7	2,13	1,02	2,58	<0.0065	<0.0286	0	0	0	0	0	0
Simeria	0,24	0,61	7,46	69,4	2,24	1,15	3,01	<0.0065	<0.0286	0	0	0	0	0	0
Geoagiu	0,32	0,36	7,39	875	23,54	0,38	32,12	<0.0065	<0.0286	0	0	0	0	0	0
Deva	0.30	0,41	7,22	74,5	1,73	0.64	3.50	<0,0062	<0,0142	0	0	0	0	0	0
Brad	0,27	0,79	7.68	393	9,91	0,77	7,66	<0,0062	<0,0142	0	0	0	0	0	0

Nota:

- ** Nici o modificare anormala.
- CMA – concentratie maxima admisa conf Ordonanta 7/2023, HG 971/2023