

Valori medii saptamanale ale parametrilor de potabilitate (12.08.2024– 18.08.2024)

Punct de recoltare	Parametrii analizati														
	Clor rezidual liber [mg/l]	Turbiditate [NTU]	pH [unitati pH]	Conductivitate [μS/cm]	Duritate [°G]	Subst. organice [mgO ₂ /l]	Cloruri [mg/l]	Nitriti [mg/l]	Amoniu [mg/l]	Bacterii coliforme [nr/100 ml]	E. coli [nr/100 ml]	Enterococi intestinali [nr/100 ml]	UFC 37°C/ml	UFC 22°C/ml	Clostridium Perfringens
CMA	0.1-0.5	4	6.5-9.5	2500	min 5	5	250	0.5	0.5	0	0	0	**	**	0
Hateg	0,36	0,38	7,5	71,95	1,61	0,65	<2,00	<0,0058	<0,0222	0	0	0	0	0	0
Hunedoara	0,41	0,6	7,51	85,48	2,36	0,51	1,72	<0.0065	<0.0286	0	0	0	0	0	0
Calan	0,28	0,70	7,50	69,3	2,15	0,96	2,58	<0.0065	<0.0286	0	0	0	0	0	0
Simeria	0,26	0,58	-	-	-	-	-	<0.0065	<0.0286	0	0	0	0	0	0
Geoagiu	0,37	0,21	-	-	-	-	-	<0.0065	<0.0286	0	0	0	0	0	0
Deva	0.27	0,48	7,04	78,6	1,79	0,64	4.67	<0,0062	<0,0142	0	0	0	0	0	0
Brad	0,29	0,89	7.41	408	9,02	0,58	7,33	<0,0062	<0,0142	0	0	0	0	0	0

Nota:

- ** Nici o modificare anormala.
- CMA – concentratie maxima admisa conf Ordonanta 7/2023, HG 971/2023