

Valori medii saptamanale ale parametrilor de potabilitate (30.09 – 06.10.2024)

| Punct de recoltare | Parametrii analizati | | | | | | | | | | | | | | |
|---|-------------------------------|----------------------|--------------------|---------------------------|------------------|--|-------------------|-------------------|------------------|-----------------------------------|------------------------|--|-------------|-------------|----------------------------|
| | Clor rezidual liber [mg/l] | Turbiditate [NTU] | pH [unitati pH] | Conductivitate [μS/cm] | Duritate [°G] | Subst. organice [mgO ₂ /l] | Cloruri [mg/l] | Nitriti [mg/l] | Amoniu [mg/l] | Bacterii coliforme [nr/100 ml] | E. coli [nr/100 ml] | Enterococi intestinali [nr/100 ml] | UFC 37°C/ml | UFC 22°C/ml | Clostridium Perfringens |
| Valori admise (Ordonanta 7/2023) | 0.1-0.5 | 4 | 6.5-9.5 | 2500 | min 5 | 5 | 250 | 0.5 | 0.5 | 0 | 0 | 0 | ** | ** | 0 |
| Hateg | 0,32 | 0,49 | 7,2 | 61,41 | 1,56 | 0,62 | <2,00 | <0,0058 | <0,0222 | 0 | 0 | 0 | 0 | 0 | 0 |
| Hunedoara | 0,34 | 1,43 | 7,40 | 79,43 | 2,19 | 1,04 | 2,52 | <0,0065 | <0,0286 | 0 | 0 | 0 | 0 | 0 | 0 |
| Calan | 0,33 | 0,61 | 7,34 | 60,9 | 1,92 | 0,83 | 1,29 | <0,0065 | <0,0286 | 0 | 0 | 0 | 0 | 0 | 0 |
| Simeria | 0,21 | 0,58 | 7,33 | 62,5 | 1,57 | 0,64 | 2,15 | <0,0065 | <0,0286 | 0 | 0 | 0 | 0 | 0 | 0 |
| Geoagiu | 0,45 | 0,21 | 7,45 | 882 | 23,44 | 0,32 | 29,68 | <0,0065 | <0,0286 | 0 | 0 | 0 | 0 | 0 | 0 |
| Deva | 0,37 | 0,44 | 7,17 | 68,7 | 1,70 | 0,62 | 2,67 | <0,0062 | <0,0142 | 0 | 0 | 0 | 0 | 0 | 0 |
| Brad | 0,47 | 0,80 | 7,23 | 426 | 10,39 | 0,52 | 8,00 | <0,0062 | <0,0142 | 0 | 0 | 0 | 0 | 0 | 0 |

Nota:

- ** Nici o modificare anormala.